UTAH COLLEGE OF APPLIED TECHNOLOGY - UINTAH BASIN
ATC PAINT BOOTH

DFCM PROJECT NO. 05078250

STATE PROPERTY ID NO.

1100 E Lagoon St.

Roosevelt, Utah 84066-3000

State of Utah– Department of Administrative Services

DIVISION OF FACILITIES CONSTRUCTION AND MANAGEMENT

4110 State Office Building / Salt Lake City, Utah 84114 / 538–3018

NOVEMBER 9, 2005

State of Utah
Department of Administrative Services

Division of Facilities Construction & Management
4110 State Office Building
Salt Lake City, Utah 84114
Phone: (801) 538 - 3018
Fax: (801) 538 - 3267

Internet: http://www.dfcm.state.ut.us

CREATED BY: P+A architects

P+A architects
821 East Kensington Ave.
Salt Lake City, Utah 84105
P: 801.484.1161
F: 801.485.4640
e-mail parchitects@comcast.net

BUILDING NAME:

UINTAH BASIN APPLIED TECH COLLEGE

PROJECT TITLE:

UINTAH BASIN APPLIED TECH. COLLEGE PAINT BOOTH EXPANSION

MARK	DATE	DESCRIPTION

ISSUE TYPE: CONSTRUCTION DOCUMENTS

ISSUE DATE: NOVEMBER 9, 2005

DFCM PROJECT NO: 05078250
CAD PROJECT NO: 2005-11
CAD DWG FILE:
DRAWN BY: BRIAN & SCOTT
CHK'D BY: SCOTT

SHEET TITLE

COVER SHEET

SHEET NUMBER

A-GI000

SHEET 1 OF 15

UTAH COLLEGE OF APPLIED TECHNOLOGY
UINTAH BASIN ATC

PAINT BOOTH VENT SYSTEM EXPANSION

D.F.C.M. PROJECT NUMBER: 05078250

1100 East Lagoon St.
Roosevelt, Utah 84066-3000

ABBREVIATIONS

Reference to materials or methods have been made on the drawings in accordance with the following abbreviations:

#	NUMBER	GWB.	GYPSUM WALL BOARD
'	FEET	GYP. BD.	GYPSUM WALL BOARD
"	INCHES	HC.	HANDICAPPED
&	AND	HDW.	HARDWARE
@	AT	H.M.	HOLLOW METAL
∅	DIAMETER	HORIZ.	HORIZONTAL
ADJ	ADJUSTABLE	HR.	HOUR
AFF	ABOVE FINISH FLOOR	HT.	HEIGHT
ALUM	ALUMINUM	HVAC	HEATING/VENTILATION/ AIR CONDITIONING
ASTM	AMERICAN SOCIETY FOR TESTING MATERIALS	HYD	HYDRANT
ATS	AUTOMATIC TRANSFER SWITCH	I.D.	INSIDE DIAMETER
		INFO	INFORMATION
BD	BOARD	INSUL.	INSULATION
BITUM.	BITUMINOUS	LAV.	LAVATORY
BLDG	BUILDING	LT.	LIGHT
B.M.	BENCHMARK	MATL.	MATERIAL
B.O.	BOTTOM OF	MAX.	MAXIMUM
BRG.	BEARING	MECH.	MECHANICAL
BTWN.	BETWEEN	MFR.	MANUFACTURER
CER.	CERAMIC	MIN.	MINIMUM
CJ	CONSTRUCTION JOINT	MISC.	MISCELLANEOUS
CLG.	CEILING	M.O.	MASONRY OPENING
CLR.	CLEAR	MTL.	METAL
CMU	CONCRETE MASONRY UNIT	NIC	NOT IN CONTRACT
COL.	COLUMN	NO.	NUMBER
CONC.	CONCRETE	N.T.S.	NOT TO SCALE
CONT.	CONTINUOUS	O.C.	ON CENTER
CONST.	CONSTRUCTION	O.D.	OUTSIDE DIAMETER
COORD.	COORDINATE	O.H.	OVERHEAD
CTJ	CONTRACTION JOINT	OPP.	OPPOSITE
DBL.	DOUBLE	PART.	PARTITION
DPW	DIRECTOR OF PUBLIC WORKS	PERP.	PERPENDICULAR
DIA.	DIAMETER	PL.	PLATE
DPG	DUGWAY PROVING GROUND	PNTD.	PAINTED
DTL.	DETAIL	PSI	POUNDS PER SQUARE INCH
DWGS.	DRAWINGS	R.D.	ROOF DRAIN
EA.	EACH	RAD.	RADIUS
EJ	EXPANSION JOINT	REINF.	REINFORCED
ELEV.	ELEVATION	REQ'D	REQUIRED
EQ.	EQUAL	RET.	RETURN
E.S.	EACH SIDE	REV.	REVERSED
EXIST.	EXISTING	RM.	ROOM
EXPAN.	EXPANSION	R.O.	ROUGH OPENING
EXT.	EXTERIOR	SCHED.	SCHEDULE
E.W.C.	ELECTRIC WATER COOLER	SHR.	SHOWER
F.D.	FLOOR DRAIN	SHT.	SHEET
FDN.	FOUNDATION	SIM.	SIMILAR
F.E.	FIRE EXTINGUISHER	SPEC.	SPECIFICATION
F.E.C.	FIRE EXTINGUISHER CABINET	STD.	STANDARD
F.F.	FINISH FLOOR	STR.	STRUCTURAL
FIN.	FINISH	SUSP.	SUSPENDED
FLR.	FLOOR	THRU	THROUGH
F.L.	FLOW LINE	T.O.	TOP OF
FTG.	FOOTING	T.O.A.	TOP OF ASPHALT
GA.	GAGE	T.O.C.	TOP OF CURB
GALV.	GALVANIZED	T.O.F.	TOP OF FOOTING
GF-CI	GOVERNMENT FURNISHED CONTRACTOR INSTALLED	T.O.S.	TOP OF SLAB OR SIDEWALK
		T.O.W.	TOP OF WALL
GF-GI	GOVERNMENT FURNISHED GOVERNMENT INSTALLED	TYP.	TYPICAL
		VERT.	VERTICAL
G.I.	GALVANIZED STEEL	VEST.	VESTIBULE
GND.	GROUND	W/	WITH
GOVT.	GOVERNMENT	WD	WOOD

DESIGN TEAM

ARCHITECT
P+A ARCHITECTS
CONTACT: SCOTT PRIOR
821 EAST KENSINGTON AVENUE
SALT LAKE CITY, UTAH 84105
PHONE: 801.484.1161
FAX: 801.485.4640

MECHANICAL
SPECTRUM ENGINEERS, INC.
CONTACT: STEVE SHEPHERD
175 SOUTH MAIN STREET, SUITE 300
SALT LAKE CITY, UTAH 84111
PHONE: 801.328.5151
FAX: 801.328.5155

STRUCTURAL
SHEN ENGINEERS, INC.
CONTACT: HENRY SHEN
3335 SOUTH 900 EAST, SUITE 250
SALT LAKE CITY, UTAH 84106
PHONE: 801.466.2625
FAX: 801.466.2656

ELECTRICAL
SPECTRUM ENGINEERS, INC.
CONTACT: STEVE SHEPHERD
175 SOUTH MAIN STREET, SUITE 300
SALT LAKE CITY, UTAH 84111
PHONE: 801.328.5151
FAX: 801.328.5155

LIST OF DRAWINGS

GRAPHIC KEY



GENERAL NOTES

1. SUBCONTRACTORS SHALL FAMILIARIZE THEMSELVES WITH ALL PORTIONS OF THE DRAWINGS, SPECIFICATIONS AND ADDENDA THAT PERTAIN TO THEIR WORK. THEY SHALL BE HELD RESPONSIBLE FOR ADHERING TO THOSE REQUIREMENTS AND SHALL NOT PREPARE ANY BID FROM PARTIAL SETS.
2. ALL NUTS, BOLTS AND MISCELLANEOUS METAL EXPOSED TO WEATHER SHALL BE GALVANIZED UNLESS OTHERWISE NOTED.
3. ALL WORK SHALL COMPLY STRICTLY WITH THE INTERNATIONAL BUILDING CODE 2003, LATEST EDITION, AND ALL LOCAL CODES AND ORDINANCES.
4. CONTRACTOR SHALL VERIFY ALL DIMENSIONS AND SITE CONDITIONS AND SHALL REPORT ANY INCONSISTENCIES TO THE CONTRACTING OFFICER.
5. CONTRACTOR SHALL REMOVE ALL SURPLUS MATERIALS, FALSE WORK, TEMPORARY STRUCTURES, INCLUDING FOUNDATIONS AND DEBRIS OF ANY NATURE RESULTING FROM HIS OPERATIONS, AND TO PUT THE SITE IN A NEAT AND ORDERLY CONDITION.
6. DIMENSIONAL DISCREPANCIES SHALL BE CLARIFIED WITH THE CONTRACTING OFFICER
7. CONTRACTOR SHALL VERIFY LOCATIONS AND SHALL PROVIDE PROTECTION FOR UTILITIES WITHIN THE WORK AREA, WHETHER OR NOT INDICATED IN THE DRAWINGS. CONTRACTOR SHALL NOTIFY UTILITY COMPANY IMMEDIATELY SHOULD SERVICE BE INTERRUPTED.
8. IT IS THE GENERAL CONTRACTOR'S RESPONSIBILITY TO REVIEW ALL CONSTRUCTION DOCUMENTS AND VERIFY ALL WORK ASSOCIATED WITH ALL TRADES. FOR EXAMPLE, IF ELECTRICAL CONSTRUCTION DOCUMENT INDICATES A NEW ELECTRICAL SWITCH TO BE LOCATED WITHIN AN EXISTING WALL WHICH REQUIRES THE EXISTING GYPSUM BOARD TO BE CUT, PATCHED, AND REPAIRED, IT WILL BE THE GENERAL CONTRACTOR'S RESPONSIBILITY TO CUT, PLACE THE NEW ELECTRICAL AND REPAIR GYPSUM BOARD WALL.

VICINITY MAP



NOT TO SCALE

DFCM DESIGN AND CODE CRITERIA

APPLICABLE CODES

	Year		Year
International Building Code		National Electrical Code	
International Mechanical Code		Uniform Code for	
International Plumbing Code		Building Conservation	
International Fire Code		ADA Accessibility	
International Energy Conservation Code		Guildelines	

A. Occupancy and Group: _____ _____ _____ _____ _____
Change in Use: Yes _____ No _____ Mixed Occupancy: Yes _____ No _____
Special Use and Occupancy (e.g. High Rise, Covered Mall): _____

B. Seismic Design Category: _____ Design Wind Speed: _____ mph

C. Type of Construction (circle one):
I A I B II A II B III A III B IV HT V A V B

D. Fire Resistance Rating Requirements for the Exterior Walls based on the fire separation distance (in hours):
North: _____ South: _____ East: _____ West: _____

E. Mixed Occupancies: _____ Nonseparated Uses: _____

F: Sprinklers:
Required: _____ Provided: _____ Type of Sprinkler System: _____

G: Number of Stories: _____ Building Height: _____

H: Actual Area per Floor (square feet): _____

I: Tabular Area: _____

J: Area Modifications:

a) $A_a = A_t + \left[\frac{A_1 I_f}{100}\right] + \left[\frac{A_1 I_s}{100}\right]$ $\qquad I_f = 100\left[\frac{F}{P} - 0.25\right]\frac{W}{30}$

b) Sum of the Ratio Calculations for Mixed Occupancies:
$\frac{\text{Actual Area}}{\text{Allowable Area}} \leq 1$

c) Total Allowable Area for:
1) One Story: _____
2) Two Story: $A_a(2)$_____
3) Three Story: $A_a(3)$_____

d) Unlimited Area Building: Yes _____ No _____ Code Section: _____

K. Fire Resistance Rating Requirements for Building Elements (hours).

Element	Hours	Assembly Listing	Element	Hours	Assembly Listing
Exterior Bearing Walls			Floors - Ceiling Floors		
Interior Bearing Walls			Roofs - Ceiling Roofs		
Exterior Non-Bearing Walls			Exterior Doors and Windows		
Structural Frame			Shaft Enclosures		
Partitions - Permanent			Fire Walls		
Fire Barriers			Fire Partitions		
			Smoke Partitions		

L. Design Occupant Load: _____
Exit Width Required: _____ Exit Width Provided: _____

M. Minimum Number of Required Plumbing Facilities:
a) Water Closets - Required (m) _____ (f) _____ Provided (m) _____ (f) _____
b) Lavatories - Required (m) _____ (f) _____ Provided (m) _____ (f) _____
c) Bath Tubs or Showers: _____
d) Drinking Fountains: _____ Service Sinks: _____

FOOTNOTES:
1) In case of conflict with the U.S. Department of Justice Federal Registers Parts I through V - ADA Guidelines and specific reference to the International Building Code Accessibility Chapters, the more restrictive requirement shall govern.
2) Additional Code Information shall be provided at the discretion of the Building Official for Complex Buildings. Including, but not limited to:
a) High Rise Requirements.
b) Atriums.
c) Performance Based Criteria.
d) Means or Egress Analysis.
e) Fire Assembly Locator Sheet.
f) Exterior and Interior Accessibility Route.
g) Fire Stopping, Including Tested Design Number.

State of Utah
Department of Administrative Services
Division of Facilities Construction & Management
4110 State Office Building
Salt Lake City, Utah 84114
Phone: (801) 538 - 3018
Fax: (801) 538 - 3267
Internet: http://www.dfcm.state.ut.us

CREATED BY: P+A architects

P+A architects
821 East Kensington Ave.
Salt Lake City, Utah 84105
P: 801.484.1161
F: 801.485.4640
e-mail parchitects@comcast.net

ARCHITECTURE PLANNING DESIGN

BUILDING NAME:
UINTAH BASIN APPLIED TECH. COLLEGE

PROJECT TITLE:
UINTAH BASIN APPLIED TECH. COLLEGE PAINT BOOTH EXPANSION

MARK	DATE	DESCRIPTION

ISSUE TYPE: CONSTRUCTION DOCUMENTS

ISSUE DATE: NOVEMBER 9, 2005

DFCM PROJECT NO: 05078250
CAD PROJECT NO: 2005-11
CAD DWG FILE:
DRAWN BY: BRIAN AND SCOTT
CHK'D BY: SCOTT

SHEET TITLE
COVER SHEET

SHEET NUMBER
A-GI001

SHEET 2 OF 15



NORTH

01 ASP101 **SITE PLAN**
SCALE 1" = 40'-0"

REFERENCE NOTES

1. PROJECT LOCATION
2. CONTRACTOR STAGING AREA
3. EXISTING CONCRETE AND ASPHALT PATHWAYS TO REMAIN OPEN TO PEDESTRIANS AND VEHICLES AT ALL TIMES DURING CONSTRUCTION
4. CONTRACTOR VEHICLE PARKING AREA
5. CONTRACTOR VEHICLE ACCESS TO CONSTRUCTION SITE
6. GENERAL CONTRACTOR ENTRANCE
7. EDGE OF PROPERTY

GENERAL NOTES

1. GENERAL CONTRACTOR IS RESPONSIBLE FOR REPLACEMENT OF ANY SIDEWALK, CURB & GUTTER, ASPHALT, LANDSCAPING ETC. DISTURBED OR DESTROYED DURING CONSTRUCTION.
2. CONTRACTOR SHALL MAINTAIN EMERGENCY AND UTILITY VEHICLE ACCESS AT ALL TIMES TO ALL EXISTING BUILDINGS AND BUILDING ENTRANCES

LEGEND

- HATCH PATTERN INDICATES AREA OF CONSTRUCTION
- GENERAL CONTRACTOR'S & SUBCONTRACTOR'S PARKING AREA
- GENERAL CONTRACTOR'S STAGING AREA
- CONTRACT LIMIT LINE

State of Utah
Department of Administrative Services

Division of Facilities
Construction & Management
4110 State Office Building
Salt Lake City, Utah 84114
Phone: (801) 538 - 3018
Fax: (801) 538 - 3267

Internet: http://www.dfcm.state.ut.us

CREATED BY: P+A architects

P+A architects
821 East Kensington Ave.
Salt Lake City, Utah 84105
P: 801.484.1161
F: 801.485.4640
e-mail parchitects@comcast.net

STATE OF UTAH · SCOTT R. [illegible] · 281119 · LICENSED ARCHITECT · 11/9/05

ARCHITECTURE PLANNING DESIGN

BUILDING NAME:

UINTAH BASIN APPLIED TECH COLLEGE

PROJECT TITLE:

UINTAH BASIN APPLIED TECH. COLLEGE PAINT BOOTH EXPANSION

MARK	DATE	DESCRIPTION

ISSUE TYPE: CONSTRUCTION DOCUMENTS

ISSUE DATE: NOVEMBER 9, 2005

DFCM PROJECT NO: 05078250
CAD PROJECT NO: 2005-11
CAD DWG FILE:
DRAWN BY: BRIAN AND SCOTT
CHK'D BY: SCOTT

SHEET TITLE

SITE PLAN

SHEET NUMBER

A-SP101



PLAN NORTH

T-01.dwg 02 ADP101 **DEMOLITION FLOOR PLAN**
SCALE 1/4" = 1'-0"



PLAN NORTH

dcl-plan.dwg 01 ADP101 **REFLECTED CEILING DEMOLITION PLAN**
SCALE 1/4" = 1'-0"

DEMOLITION FLOOR PLAN REFERENCE NOTES

1. DASHED LINE INDICATES LOCATION WHERE GENERAL CONTRACTOR SHALL SAW CUT EXISTING FLOOR SLAB.
2. GENERAL CONTRACTOR SHALL SAW CUT EXISTING MASONRY WALL AT LOCATION SHOWN.
3. EXISTING MASONRY BUILDING WALL NOT TO BE DISTURBED
4. GENERAL CONTRACTOR SHALL PROVIDE ADEQUATE SUPPORT FOR MASONRY ABOVE DOOR THAT IS TO REMAIN, SEE STRUCTURAL DRAWINGS ON CONNECTION BETWEEN EXISTING & NEW MASONRY ABOVE DOOR.
5. EXISTING DOOR & FRAME TO REMAIN
6. EXISTING PAINT BOOTH FILTER NOT TO BE DISTURBED

DEMO FLOOR PLAN LEGEND

HATCH PATTERN INDICATES EXISTING CONCRETE FLOOR SLAB TO BE REMOVED

HATCH PATTERN INDICATES EXISTING MASONRY WALL TO BE REMOVED, SEE SECTIONS

GENERAL NOTES

1. THE GENERAL CONTRACTOR SHALL REPLACE ALL CONCRETE FLOORING DAMAGED DURING DEMOLITION AND CONSTRUCTION
2. THE GENERAL CONTRACTOR SHALL REMOVE ALL OVER SPRAY FROM EXISTING PAINT BOOTH FLOOR SLAB PRIOR TO BEGINNING WORK.

DEMOLITION CEILING PLAN REFERENCE NOTES

1. EXISTING SURFACE MOUNTED CONDUIT TO BE REMOVED
2. EXISTING GUARD RAILING ABOVE TO BE SUPPORTED DURING CONSTRUCTION. GENERAL CONTRACTOR SHALL ATTACH GUARD RAILING TO NEW STRUCTURAL MEMBER, SEE DETAIL
3. DASHED LINE INDICATES CENTER LINE OF 2X CONNECTED TO BOTTOM OF JOIST ABOVE. GENERAL CONTRACTOR SHALL CUT EXISTING GYPSUM BOARD AT CENTER LINE TO PROVIDE A SURFACE TO ATTACH NEW & EXISTING GYPSUM BOARD CEILING.
4. GENERAL CONTRACTOR SHALL PROVIDE ADEQUATE SUPPORT FOR MASONRY ABOVE DOOR THAT IS TO REMAIN, SEE STRUCTURAL DRAWINGS ON CONNECTION BETWEEN EXISTING & NEW MASONRY ABOVE DOOR.

DEMO CEILING PLAN LEGEND

HATCH PATTERN INDICATES EXISTING GYPSUM BOARD CEILING TO BE REMOVED. REMOVE CEILING BACK TO CENTERLINE OF CLOSEST EXISTING JOIST

E — EXISTING EXPLOSION PROOF LIGHT FIXTURE TO BE REMOVED & REINSTALLED AS PER NEW CEILING PLAN

E.F.S. — EXISTING FIRE SPRINKLER HEAD TO BE REMOVED & REPLACED W/ NEW FIRE-SPRINKLER HEAD

State of Utah
Department of Administrative Services

Division of Facilities Construction & Management
4110 State Office Building
Salt Lake City, Utah 84114
Phone: (801) 538 - 3018
Fax: (801) 538 - 3267

Internet: http://www.dfcm.state.ut.us

CREATED BY: P+A architects

P+A architects
821 East Kensington Ave.
Salt Lake City, Utah 84105
P: 801.484.1161
F: 801.485.4640
e-mail parchitects@comcast.net

STATE OF UTAH SCOTT A. PRICE 261110 LICENSED ARCHITECT 11/9/05

ARCHITECTURE PLANNING DESIGN

BUILDING NAME:

UINTAH BASIN APPLIED TECH. COLLEGE

PROJECT TITLE:

UINTAH BASIN APPLIED TECH. COLLEGE PAINT BOOTH EXPANSION

MARK	DATE	DESCRIPTION

ISSUE TYPE: CONSTRUCTION DOCUMENTS

ISSUE DATE: NOVEMBER 9, 2005

DFCM PROJECT NO: 05078250
CAD PROJECT NO: 2005-11
CAD DWG FILE:
DRAWN BY: BRIAN AND SCOTT
CHK'D BY: SCOTT

SHEET TITLE

DEMOLITION FLOOR PLAN AND REFLECTED CEILING PLAN

SHEET NUMBER

A-DP101



NEW FLOOR PLAN

PLAN NORTH

03 / AFP101 — SCALE 1/4" = 1'-0"



REFLECTED CEILING PLAN

PLAN NORTH

02 / AFP101 — SCALE 1/4" = 1'-0"



WALL TYPES

01 / AFP101 — SCALE 3" = 1'-0"

FLOOR PLAN REFERENCE NOTES

1. EXISTING HOLLOW METAL DOOR & FRAME TO REMAIN UNDISTURBED. DOOR & FRAME TO BE REPAINTED
2. NEW FILTER & FIRE DAMPER SYSTEM TO BE LOCATED AS SHOWN.
3. NEW ATLAS BRICK WALL, BRICK COLOR FINISH & SIZE TO MATCH EXISTING
4. NEW DOOR, SEE SCHEDULE

FLOOR PLAN LEGEND

- 100A — DOOR NUMBER
- ROOM NAME / 100 — ROOM NAME AND NUMBER
- 01 — WALL TYPE

REFLECTED CEILING PLAN REFERENCE NOTES

1. CEILING CONSTRUCTION AS PER GYPSUM ASSOCIATION GA FILE NO. WP 6800

REFLECTED CEILING PLAN GENERAL NOTES

1. ALL SWITCHES, OUTLETS, CONDUITS, JUNCTION BOXES, LIGHT FIXTURES, ETC. TO BE EXPLOSION PROOF
2. ALL ELECTRICAL EQUIPMENT & LIGHTING IS SHOWN FOR SCHEMATIC PURPOSES ONLY. IT IS THE GENERAL CONTRACTOR'S RESPONSIBILITY TO PROVIDE DESIGN BUILD ELECTRICAL USING EXISTING ELECTRICAL SYSTEMS. IT IS THE GENERAL CONTRACTOR'S RESPONSIBILITY TO HAVE THEIR ELECTRICAL SUBCONTRACTOR REVIEW THE PROJECT PRIOR TO BIDDING. ALL ELECTRICAL MUST MEET CURRENT NEC CRITERIA.
3. GENERAL CONTRACTOR SHALL REVIEW VOLTAGE OF EXISTING LIGHTING PRIOR TO BIDDING TO DETERMINE IF EXISTING LIGHTING IS 120 VOLT SYSTEM.
4. NEW CONDUIT FOR LIGHT FIXTURES TO BE SURFACE MOUNTED

CEILING PLAN LEGEND

- E — EXISTING EXPLOSION PROOF SURFACE MOUNTED LIGHT FIXTURE TO BE RELOCATED TO NEW LOCATION AS SHOWN
- NEW EXPLOSION PROOF LIGHT FIXTURE
- NEW EXPLOSION PROOF LIGHT SWITCH
- N — NEW FIRE-SPRINKLER HEAD. GENERAL CONTRACTOR TO EXTEND EXISTING LINE TO NEW LOCATION AS SHOWN. GENERAL CONTRACTOR SHALL VERIFY SPRINKLER HEAD TYPE REQUIRED FOR SPACE.

LIGHT FIXTURE SCHEDULE

SYMBOL	FIXTURE VOLTAGE	LAMPS #	LAMP TYPE	DESCRIPTON, MANUFACTURER AND CAT. NO.
N	120	1	INCANDESCENT 150 WATT	EXPLOSION PROOF, CEILING MOUNTED LIGHT FIXTURE. APPLETON ELECTRIC, A-51 SERIES GROUPS A&B WITH ALUMINUM GUARD

State of Utah
Department of Administrative Services
Division of Facilities Construction & Management
4110 State Office Building
Salt Lake City, Utah 84114
Phone: (801) 538 - 3018
Fax: (801) 538 - 3267
Internet: http://www.dfcm.state.ut.us

CREATED BY: P+A architects

P+A architects
821 East Kensington Ave.
Salt Lake City, Utah 84105
P: 801.484.1161
F: 801.485.4640
e-mail parchitects@comcast.net

ARCHITECTURE | PLANNING | DESIGN

BUILDING NAME:

UINTAH BASIN APPLIED TECH. COLLEGE

PROJECT TITLE:

UINTAH BASIN APPLIED TECH. COLLEGE PAINT BOOTH EXPANSION

MARK	DATE	DESCRIPTION

ISSUE TYPE: CONSTRUCTION DOCUMENTS

ISSUE DATE: NOVEMBER 9, 2005

DFCM PROJECT NO: 05078250
CAD PROJECT NO: 2005-11
CAD DWG FILE:
DRAWN BY: BRIAN AND SCOTT
CHK'D BY: SCOTT

SHEET TITLE

FLOOR PLAN AND REFLECTED CEILING PLAN

SHEET NUMBER

A-FP101

SHEET 5 OF 15

DIVISION 16 – ELECTRICAL

GENERAL REQUIREMENTS

GENERAL CONDITIONS: THE GENERAL CONDITIONS, SUPPLEMENTARY GENERAL CONDITIONS, SPECIAL CONDITIONS, ALTERNATES AND ADDENDA, APPLICABLE DRAWINGS AND TECHNICAL SPECIFICATIONS SHALL APPLY TO ALL WORK UNDER THIS DIVISION.

STATE LICENSED CONTRACTOR – THE CONTRACTOR SHALL HAVE A CURRENT STATE ELECTRICAL CONTRACTING LICENSE.

SCOPE

THE WORK COVERED BY THESE DOCUMENTS CONSISTS OF FURNISHING ALL LABOR, MATERIALS, EQUIPMENT, SUPERVISION AND SERVICES NECESSARY TO FILL THE INTENT AND PURPOSE OF THE ELECTRICAL WORK SHOWN ON THE DRAWINGS AND HEREINAFTER SPECIFIED. ITEMS OMITTED FROM EITHER THE DRAWINGS OR SPECIFICATIONS, BUT SHOWN OR DESCRIBED IN THE OTHER, AND/OR ALL ITEM NECESSARY MAKE THE ELECTRICAL SYSTEM COMPLETE AND WORKABLE SHALL BE UNDERSTOOD TO FORM A PART OF THE WORK.

MATERIALS AND WORKMANSHIP

ALL MATERIALS AND EQUIPMENT FURNISHED AND INSTALLED SHALL BE OF THE HIGHEST QUALITY, NEW AND MEET THE STANDARDS OF NEMA, IPCEA, LS, UL, NFPA, UBS, OSH, NEC, AND SHALL BEAR THEIR LABEL WHEREVER STANDARDS HAVE BEEN ESTABLISHED AND LABEL SERVICE IS AVAILABLE. WHERE MATERIALS AND EQUIPMENT ARE SPECIFIED BY MANUFACTURER'S NAME, THE TYPE AND QUALITY REQUIRED IS THEREBY DENOTED. THE ARCHITECT SHALL BE AFFORDED EVERY FACILITY DEEMED NECESSARY TO INSPECT AND EXAMINE THE MATERIALS AND APPARATUS BEING INSTALLED TO PROVE THEIR QUALITY, SKILL AND COMPETENCY OF WORKMANSHIP.

CODES– REGULATION AND PERMITS

IN THE INSTALLATION OF THIS WORK, COMPLY WITH THE REQUIREMENTS OF THE LAWS, ORDINANCES AND RULES OF THE STATE AND NATIONAL BOARD OF FIRE UNDERWRITERS, THE NATIONAL ELECTRICAL CODE, AND THE RULES AND REGULATIONS OF LOCAL ORDINANCES.

IF A CONFLICT OCCURS BETWEEN THESE RULES AND DOCUMENTS, THE RULES ARE TO GOVERN. THE CONTRACTOR ACCEPTS THIS RESPONSIBILITY UPON SUBMITTING HIS BID, AND NO EXTRA CHARGE WILL BE ALLOWED AFTER THE ELECTRICAL CONTRACT IS AWARDED. THIS SHALL NOT BE CONSTRUED AS RELIEVING THE CONTRACTOR FROM COMPLYING WITH ANY REQUIREMENTS OF THE PLANS OR SPECIFICATIONS WHICH MAY BE IN EXCESS OF REQUIREMENTS OF THE HEREIN MENTIONED RULES AND NOT CONTRARY TO SAME. ALL MATERIALS AND EQUIPMENT INSTALLED, INCLUDING LIGHTING FIXTURES, SHALL HAVE BEEN TESTED AND APPROVED BY UNDERWRITER'S LABORATORY AND SHALL BE SE LABELED, UNLESS OTHERWISE APPROVED BY THE ARCHITECT.

ARCHITECTURAL AND MECHANICAL DOCUMENTS ARE CONSIDERED A PART OF THE ELECTRICAL DOCUMENTS INSOFAR AS THEY APPLY, AS IF REFERRED TO IN FULL.

SINCE THE DRAWINGS OF THE FLOOR AND CEILING INSTALLATION ARE MADE AT A SMALL SCALE, OUTLETS, DEVICES, EQUIPMENT, ETC., ARE INDICATED ONLY IN THEIR APPROXIMATE LOCATION, UNLESS DIMENSIONED. LOCATE OUTLETS AND APPARATUS SYMMETRICALLY ON FLOORS, WALL AND CEILING WHERE NOT DIMENSIONED, AND COORDINATE SUCH LOCATIONS WITH WORK OF OTHER TRADES TO PREVENT INTERFERENCES. ALL DIMENSIONS ON THE JOB SHALL BE VERIFIED. DO NOT SCALE THE ELECTRICAL DRAWINGS, BUT REFER TO THE ARCHITECTURAL AND MECHANICAL DRAWINGS FOR DIMENSIONS.

UPON COMPLETION OF THE INSTALLATION, FURNISH A SET OF "RECORD" DRAWINGS TO THE ARCHITECT CLEARLY MARKED WITH THE CHANGES AUTHORIZED DURING CONSTRUCTION. ALSO SUBMIT WARRANTIES, OPERATION AND MAINTENANCE DATA ON ALL ITEMS OF EQUIPMENT.

ALL ELECTRICAL WORK SHALL COMPLY WITH ALL REQUIREMENTS OF THE I.C.C. ELECTRICAL CODE REQUIREMENTS FOR SPRAY BOOTHS & SPRAY ROOMS.

STORAGE AND PROTECTION OF MATERIALS

PROVIDE STORAGE SPACE FOR MATERIALS AND APPARATUS AND ASSUME COMPLETE RESPONSIBILITY FOR ALL LOSSES DUE TO ANY CAUSE WHATSOEVER. IN NO CASE SHALL STORAGE INTERFERE WITH TRAFFIC CONDITIONS IN ANY PUBLIC THOROUGHFARE OR CONSTITUTE A HAZARD TO PERSONS IN THE VICINITY. PROTECT COMPLETED WORK, WORK UNDERWAY, AND APPARATUS AGAINST LOSS OR DAMAGE.

SHOP DRAWINGS

SHOP OR DETAIL DRAWINGS SHALL BE SUBMITTED IN QUADRUPLE TO THE ARCHITECT PRIOR TO INSTALLATION OF ANY EQUIPMENT WHEN SHOP DRAWINGS ARE REQUIRED, AS HEREINAFTER SPECIFIED.

CONTRACTOR SHALL PREPARE AND SUBMIT ANY DETAIL DRAWINGS AT ANY TIME SUCH DRAWINGS ARE DEEMED NECESSARY BY THE ARCHITECT AND SHALL OBTAIN WRITTEN APPROVAL OF SAME BEFORE PROCEEDING WITH THE INSTALLATION OF THE WORK.

SHOP DRAWINGS SHALL BE SUBMITTED IN PROPERLY BOUND AND INDEXED BROCHURES. LIGHTING FIXTURE BROCHURE'S SHALL INCLUDE FIXTURE TYPE NUMBERS, MANUFACTURER, AND CATALOG NUMBERS. SPECIAL FEATURES NOT NORMALLY INCLUDED AS STANDARD, SHALL BE LABELED.

TESTING

CONTRACTOR SHALL TEST THE SYSTEM IN THE PRESENCE OF THE PROJECT MANAGER OR HIS DESIGNATED REPRESENTATIVE, AND DEMONSTRATE ALL EQUIPMENT AS WORKING AND OPERATING. ALL GROUNDINGS, OPENS, SHORTS OR OTHER DEFECTS SHALL BE RECTIFIED AT NO EXTRA COST TO THE OWNER BEFORE ACCEPTANCE AND PAYMENT.

GUARANTEE

THE ENTIRE ELECTRICAL SYSTEM INSTALLED UNDER THIS CONTRACT SHALL BE LEFT IN PROPER WORKING ORDER AND BE IN COMPLIANCE WITH THE DRAWINGS, SPECIFICATIONS AND/OR AUTHORIZED CHANGES TO THE SATISFACTION OF THE OWNER'S REPRESENTATIVE.

WITHOUT ADDITIONAL CHARGE, REPLACE ANY WORK OR MATERIALS WHICH DEVELOP DEFECTS, EXCEPT FROM ORDINARY WEAR AND TEAR, WITHIN ONE YEAR FROM THE DATE OF FINAL ACCEPTANCE.
EXCEPTION: INCANDESCENT AND FLUORESCENT LAMPS, WHICH SHALL BE GUARANTEED FOR A PERIOD OF TWO MONTHS FROM ACCEPTANCE OF THE INSTALLATION BY THE OWNER OR HIS AGENT. A WRITTEN GUARANTEE COVERING THE ABOVE PROVISIONS SHALL BE SIGNED AND DELIVERED TO THE ARCHITECT AFTER THE PROJECT HAS FINAL ACCEPTANCE BY THE INSPECTING AUTHORITY.

TEMPORARY FACILITIES

PROVIDE, FOR USE OF OTHER TRADES DURING CONSTRUCTION PERIOD, REQUIRED TEMPORARY ELECTRICAL POWER, COMPLETE WITH REQUIRED MAIN BREAKER, SWITCH PANEL, METER, POLES, CONDUCTORS, ETC.
SEE DIVISION 2.

AT COMPLETION OF WORK, OR WHEN SO ORDERED BY ARCHITECT OR CONTRACTOR, REMOVE FROM SITE ALL PARTS OF TEMPORARY ELECTRICAL SERVICES, LEAVING NO DISCERNIBLE SCARS. CONTRACTOR MAY CONNECT AND USE LIGHTING FIXTURES AS DESIGNATED BY ARCHITECT FOR LIGHTING DURING CONSTRUCTION. REPLACE BULBS AND OTHER PARTS OF LIGHTING FIXTURES DAMAGES OR BURNED OUT DURING SUCH USE AT COMPLETION OF WORK AT NO ADDITIONAL COST TO OWNER.

SYSTEMS

SYSTEM IS 120/240 VOLTS, SINGULAR PHASE, 3-WIRE, 60 Hz.

GROUNDING

THE NEUTRAL CONDUCTOR AND CABINET, CONDUITS, APPLIANCES, EQUIPMENT, SHALL BE BONDED TO THE GROUNDING SYSTEM IN ACCORDANCE WITH REQUIREMENTS OF THE NATIONAL ELECTRIC CODE.

CONDUIT SYSTEMS

ELECTRICAL METALLIC TUBING SHALL BE USED WHERE SIZES 4" AND SMALLER ARE REQUIRED, EXCEPT WHERE INSTALLED IN EARTH, CONCRETE SLABS ADJACENT TO EARTH, OR IN LOCATIONS WHERE SUBJECT TO MECHANICAL INJURY. IN ALL SUCH CASES, POLYVINYL CHLORIDE CONDUIT SHALL BE USED. TUBING MAY BE USED IN SLABS ABOVE GRADE LEVEL.

INTERMEDIATE METALLIC TUBING SYSTEMS SHALL UTILIZE RAIN TIGHT COMPRESSION CONNECTORS OR SET SCREW TYPE FITTINGS THROUGHOUT. CRIMPON INDENTER TYPE FITTINGS WILL NOT BE ACCEPTABLE. PRECAUTION SHALL BE EXERCISED TO PREVENT ACCUMULATION OF WATER, DIRT, OR CONCRETE IN THE CONDUITS DURING THE EXECUTION OF THE WORK.

CONDUITS IN WHICH WATER OR FOREIGN MATTER HAS BEEN PERMITTED TO ACCUMULATE SHALL BE THOROUGHLY CLEANED OR THE CONDUIT RUNS REPLACED WHERE SUCH ACCUMULATION CANNOT BE REMOVED BY METHODS APPROVED BY THE ARCHITECT. NO WIRE SHALL BE INSTALLED UNTIL WORK WHICH MIGHT CAUSE DAMAGE TO THE WIRE OR CONDUIT HAD BEEN COMPLETED. CONDUIT WHICH HAS BEEN CRUSHED OR DEFORMED IN ANY MANNER SHALL NOT BE INSTALLED. CONDUIT RUNS SHALL BE KEPT A MINIMUM DISTANCE OF 6 INCHES FROM HOT WATER AND STEAM PIPES.

CONDUIT, TUBING, AND BOXES SHALL BE SUPPORTED IN AN APPROVED MANNER BY MEANS OF EXPANSION SHIELDS OR EMBEDDED SUPPORTS IN CONCRETE OR SOLID MASONRY, TOGGLE BOLTS ON HOLLOW MASONRY UNITS, WOOD SCREWS ON WOOD AND METAL SCREWS ON METAL. WOODEN PLUGS INSERTED IN CONCRETE OR MASONRY UNITS SHALL NOT BE USED AS A BASE FOR FASTENING CONDUITS, TUBING, BOXES, CABINETS, ETC.

ALL RACEWAYS 3/4" AND LARGER SHALL UTILIZE OZ TYPE "A" INSULATING BRUSHING AT CABINET AND OUTLETS.

RACEWAY ENTERING OUTLETS OF CABINETS SHALL HAVE DOUBLE LOCK NUTS APPLIED FOR GROUNDING PURPOSES AND THEN INSULATING BRUSHING APPLIED OVER LOCK NUT.

ALL EMPTY CONDUITS SHALL HAVE A 200 POUND NYLON PULL WIRE.

CONDUCTORS

CONDUCTORS FOR FEEDERS AND BRANCH CIRCUITS, UNLESS NOTED OTHERWISE, SHALL BE COPPER. INSULATION SHALL BE TYPE THW. NEUTRAL CONDUCTORS SHALL BE THE SIZES INDICATED ON THE RISER DIAGRAM. SIZES SMALLER THAN #12 AWG SHALL NOTE BE USED IN BRANCH CIRCUITS. SIZES #8 AND LARGER SHALL BE STANDARD.

PHASE A – BLACK
PHASE B – RED
NEUTRAL – WHITE
GROUND – GREEN



05 AEL201 **FILTER ELEVATION**
SCALE 1" = 1'-0"
8-01.dwg



04 AEL201 **FILTER DETAIL**
SCALE 3" = 1'-0"
8-02.dwg

REFERENCE NOTES

1. EXISTING HVAC SYSTEM TO REMAIN UNDISTURBED
2. NEW 8" ATLAS BRICK WALL, BRICK COLOR FINISH & SIZE TO MATCH EXISTING
3. 1X12 PREMIUM GRADE POPLAR WOOD TRIM TO BE PRIMED AND PAINTED TO MATCH EXISTING
4. EXISTING HANDRAIL TO BE REMOVED AND REATTACHED TO NEW STRUCTURAL MEMBER, SEE SECTION
5. EXISTING AIR FILTER OPENING
6. NEW FILTER TO BE LOCATED IN MASONRY WALL AS PER ADD ALTERNATE #1, SEE DETAILS & SPECIFICATION
7. EXISTING HOLLOW METAL DOOR & FRAME TO BE PAINTED EACH SIDE
8. FINISH FLOOR
9. EXISTING BUILDING EXTERIOR WALL
10. FINISH TOP OF 1"X12" W/ FINISH TRIM TO MATCH EXISTING
11. BULLNOSE ATLAS BRICK AT CORNER
12. NEW 1 HOUR FIRE RATED SHAFT ENCLOSURE GYPSUM BOARD WALL. WALL TO BE CONSTRUCTED AS PER DETAIL 08/ADT501 GA FILE NO. WP6800
13. NEW 36"X48" FIRE RATED ACCESS DOOR, ACUDOR PRODUCTS INC. DOOR TYPE FB5060 OR PRE APPROVED EQUAL BY OTHERS.
14. PARAPET BEYOND
15. EXISTING ROOF SYSTEM & STRUCTURAL SYSTEM
16. DASHED LINES INDICATE EXISTING PAINT BOOTH EXHAUST DUCT.



03 AEL201 **BRACKET DETAIL**
SCALE 3" = 1'-0"
8-03.dwg



02 AEL201 **PARTIAL ELEVATION**
SCALE 1/4" = 1'-0"
elevation-01.dwg



01 AEL201 **PARTIAL ELEVATION**
SCALE 1/4" = 1'-0"
elevation-02.dwg

State of Utah
Department of Administrative Services

Division of Facilities Construction & Management
4110 State Office Building
Salt Lake City, Utah 84114
Phone: (801) 538 - 3018
Fax: (801) 538 - 3267

Internet: http://www.dfcm.state.ut.us

CREATED BY: P+A architects

P+A architects
821 East Kensington Ave.
Salt Lake City, Utah 84105
P: 801.484.1161
F: 801.485.4640
e-mail parchitects@comcast.net

STATE OF UTAH – SCOTT R. PRIOR – LICENSED ARCHITECT – 11/9/05

ARCHITECTURE PLANNING DESIGN

BUILDING NAME:

UINTAH BASIN APPLIED TECH. COLLEGE

PROJECT TITLE:

UINTAH BASIN APPLIED TECH. COLLEGE PAINT BOOTH EXPANSION

MARK	DATE	DESCRIPTION

ISSUE TYPE: CONSTRUCTION DOCUMENTS

ISSUE DATE: NOVEMBER 9, 2005

DFCM PROJECT NO: 05078250
CAD PROJECT NO: 2005-11
CAD DWG FILE:
DRAWN BY: BRIAN AND SCOTT
CHK'D BY: SCOTT

SHEET TITLE

PARTIAL ELEVATION AND ELECTRICAL NOTES

SHEET NUMBER

A-EL201



02 A-SC300 (D3.dwg) WALL SECTION

SCALE 1/2" = 1'-0"

01 A-SC300 (D6.dwg) WALL SECTION

SCALE 1/2" = 1'-0"

REFERENCE NOTES

1. EXISTING MASONRY WALL
2. NEW MASONRY WALL TO MATCH EXISTING MASONRY
3. CONTRACTOR SHALL CUT CONCRETE AT THIS LOCATION, SEE FLOOR PLAN
4. NEW CONCRETE SLAB
5. EXISTING CONCRETE SLAB
6. EXISTING STRUCTURE
7. NEW JOISTS, SEE STRUCTURAL
8. GLUELAM BEAM TO BE INSTALLED IN PLACE OF REMOVED WALL
9. GUARDRAIL IN THIS LOCAIONT SHALL BE REMOVED FROM EXISITNG MASONRY WALL AND REATTACHED TO GLUELAM. CONTRACTOR SHALL NOTCH PLYWOOD TO FIT AROUND GUARDRAIL
10. EXISTING GUARDRAIL
11. NEW 2X4 STUD WALL WITH 5/8" TYPE "X" GYP. BOARD ON BOTH SIDES
12. NEW DOOR BEYOND
13. CEILING CONSTRUCTION AS PER GYPSUM ASSOCIATION GA FILE NO. WP 6800
14. NEW 3/4" T&G PLYWOOD SHEATHING

GENERAL NOTES

1. --

State of Utah
Department of Administrative Services
Division of Facilities Construction & Management
4110 State Office Building
Salt Lake City, Utah 84114
Phone: (801) 538 - 3018
Fax: (801) 538 - 3267
Internet: http://www.dfcm.state.ut.us

CREATED BY: P+A architects

P+A architects
821 East Kensington Ave.
Salt Lake City, Utah 84105
P: 801.484.1161
F: 801.485.4640
e-mail parchitects@comcast.net

STATE OF UTAH CONTRACTOR REGISTRATION 11175 LICENSED ARCHITECT
ARCHITECTURE PLANNING DESIGN

BUILDING NAME:

UINTAH BASIN APPLIED TECH. COLLEGE

PROJECT TITLE:

UINTAH BASIN APPLIED TECH. COLLEGE PAINT BOOTH REMODEL

MARK	DATE	DESCRIPTION

ISSUE TYPE: CONSTRUCTION DOCUMENTS

ISSUE DATE: NOVEMBER 9, 2005

DFCM PROJECT NO: 05078250
CAD PROJECT NO: 2005-11
CAD DWG FILE:
DRAWN BY: BRIAN AND SCOTT
CHK'D BY: SCOTT

SHEET TITLE

BUILDING SECTIONS

SHEET NUMBER

A-SC300

ROOM FINISH SCHEDULE

ROOM NO.	ROOM NAME	FLOOR	BASE	WALLS NORTH	WALLS EAST	WALLS SOUTH	WALLS WEST	CEILING TYPE	CEILING HEIGHT	NOTES
100	EXISTING BOOTH	F1	–	W4	W4	W4	W4	CT–3	9'–0"	
101	NEW SPRAY ROOM	F1	B1	W2	W2	W2	W2	CT–2	9'–0"	
102	STORAGE	F1	B1	W1	W1	W3	W2	CT–1	9'–0"	

DOOR AND FRAME SCHEDULE

DOOR	SINGLE/PAIR	DOOR SIZE WxH	DOOR DEPTH	DOOR TYPE	DOOR MATL	DOOR FINISH	FRAME DEPTH	FRAME TYPE	FRAME MATL	FRAME FINISH	DETAIL HEAD	DETAIL JAMB	DETAIL THRSH	HARDWARE SET	FIRE RATING DOOR & FRAME	NOTES
102A	S	3'–0" X 7'–0"	1¾"	A	H.M.	PAINT	5¾"	01	HM	PAINT	06/ADT501	05/ADT501	–	01	NONE	

DOOR 102A HARDWARE SCHEDULE - HW SET 01

3	EA	HINGE	5BBL 4.5X4.5	652 IVE
1	EA	STOREROOM LOCK	ND80PD RHO	626 SCH
1	EA	KICK PLATE	8400 10"X2" LDW	630 IVE
1	EA	WALL STOP	W S 401 CCV	626 IVE
1	EA	SURFACE CLOSER	4041 EDA	689 LCN
1	EA	SET SEALS	5020B	BRN NGP

BASE TYPES

B–1	4" COVED RUBBER BASE

FLOOR FINISHES

F–1	SEALED CONCRETE

WALL FINISHES

W–1	EXISTING MASONRY WALL
W–2	GYPSUM BOARD WALL PRIMED & PAINTED
W–3	NEW MASONRY WALL
W–4	EXISTING PAINT BOOTH WALL TO REMAIN UNDISTURBED

CEILING TYPES

CT–1	⅝" TYPE "X" GYPSUM BOARD PRIMED AND PAINTED
CT–2	1 HR. FIRE RATED GYP. BOARD CEILING, SEE DETAIL 08/ADT501 GYPSUM BOARD CEILING TO BE PRIMED AND PAINTED.
CT–3	EXISTING PAINT BOOTH CEILING TO REMAIN UNDISTURBED



CEILING CONSTRUCTION AS PER GYPSUM ASSOCIATION GA FILE NO. WP 6800

TYPICAL FIRE RATED CEILING AND SHAFT WALL

08/ADT501 SCALE 3" = 1'–0"



DOOR AND FRAME TYPE

07/ADT501 SCALE 1/4" = 1'–0"

REFERENCE NOTES

1. EXISTING BUILDING MASONRY WALL
2. NEW WOOD 2X4 FRAMED WALL WITH ⅝" GYP. BRD. EACH SIDE
3. CONTRACTOR SHALL CUT CONCRETE AT THIS LOCATION, SEE FLOOR PLAN
4. EXISTING STRUCTURE
5. NEW JOISTS, SEE STRUCTURAL
6. WOOD BEAM TO BE INSTALLED IN PLACE OF EXISTING MASONRY WALL THAT WAS REMOVED
7. GUARDRAIL IN THIS LOCATION SHALL BE REMOVED FROM EXISTING MASONRY WALL AND REATTACHED TO NEW STRUCTURAL BEAM. CONTRACTOR SHALL NOTCH PLYWOOD TO FIT AROUND GUARDRAIL
8. EXISTING GUARDRAIL
9. NEW ATLAS BRICK WALL, BRICK COLOR, FINISH & SIZE TO MATCH EXISTING
10. NEW DOOR BEYOND
11. EXISTING DUCTWORK TO REMAIN UNDISTURBED
12. NEW 4" CONCRETE SLAB OVER 4" COMPACTED GRAVEL BASE
13. NEW FOOTING & FOUNDATION WALL, SEE STRUCTURAL
14. REPLACE PERIMETER INSULATION REMOVED OR DAMAGED ALONG THIS WALL
15. EXISTING CONCRETE FLOOR SLAB
16. EXISTING CONCRETE FOOTING & FOUNDATION SYSTEM
17. NEW AIR FILTER AND FIRE DAMPER SYSTEM AS PER ADD ALTERNATE #1
18. NEW HOLLOW METAL DOOR FRAME
19. CEILING CONSTRUCTION AS PER GYPSUM ASSOCIATION GA FILE NO. WP 6800
20. NEW ¾" T&G PLYWOOD SHEATHING
21. NEW 1 HOUR FIRE RATED SHAFT ENCLOSURE GYPSUM BOARD WALL. WALL TO BE CONSTRUCTED AS PER DETAIL 08/ADT501 GA FILE NO. WP6800
22. NEW 36"X48" FIRE RATED ACCESS DOOR, ACUDOR PRODUCTS INC. DOOR TYPE FB5060 OR PRE APPROVED EQUAL BY OTHERS.
23. PARAPET BEYOND
24. EXISTING ROOF SYSTEM & STRUCTURAL SYSTEM
25. DASHED LINES INDICATE EXISTING PAINT BOOTH EXHAUST DUCT.

GENERAL NOTES

1. REFER TO FINISH SCHEDULE FOR ADDITIONAL FINISH NOTES.







DETAIL

DETAIL_9-04.DWG 04/ADT501 SCALE 1 1/2" = 1'–0"



DETAIL

DETAIL_9-04.DWG 03/ADT501 SCALE 1 1/2" = 1'–0"

DOOR HEAD DETAIL

9-06.dwg 06/ADT501 SCALE 3" = 1'–0"

DOOR JAMB DETAIL

9-07.dwg 05/ADT501 SCALE 3" = 1'–0"



WALL SECTION

9-02.dwg 02/ADT501 SCALE 1/2" = 1'–0"



WALL SECTION

9-02.dwg 01/ADT501 SCALE 1/2" = 1'–0"

State of Utah
Department of Administrative Services
Division of Facilities Construction & Management
4110 State Office Building
Salt Lake City, Utah 84114
Phone: (801) 538 - 3018
Fax: (801) 538 - 3267
Internet: http://www.dfcm.state.ut.us

CREATED BY: P+A architects

P+A architects
821 East Kensington Ave.
Salt Lake City, Utah 84105
P: 801.484.1161
F: 801.485.4640
e-mail parchitects@comcast.net



BUILDING NAME:

UINTAH BASIN APPLIED TECH. COLLEGE

PROJECT TITLE:

UINTAH BASIN APPLIED TECH. COLLEGE PAINT BOOTH EXPANSION

MARK	DATE	DESCRIPTION

ISSUE TYPE: CONSTRUCTION DOCUMENTS

ISSUE DATE: NOVEMBER 9, 2005

DFCM PROJECT NO: 05075250
CAD PROJECT NO: 2005-11
CAD DWG FILE:
DRAWN BY: BRIAN AND SCOTT
CHK'D BY: SCOTT

SHEET TITLE

ROOM FINISH SCHEDULE, DOOR SCHEDULE ENLARGED PLANS, ELEVATIONS AND DETIALS

SHEET NUMBER

A-DT501

SHEET 8 OF 15

GENERAL STRUCTURAL NOTES:

I. GENERAL:

A. THE STRUCTURAL DRAWINGS SHOW THE COMPLETED PROJECT. DETAILS, SECTIONS, AND NOTES SHOWN ON THE DRAWINGS SHALL BE TYPICAL AND APPLY TO SIMILAR SITUATIONS ELSEWHERE UNLESS NOTED OR SHOWN OTHERWISE.
B. CONTRACTOR SHALL COMPARE ALL DIMENSIONS AND CONDITIONS ON CONTRACT DOCUMENTS AND AT THE SITE. ANY OMISSION OR CONFLICT SHALL BE BROUGHT TO THE ATTENTION OF THE ARCHITECT/ENGINEER. IN CASE OF ANY CONFLICT FOLLOW THE MOST STRINGENT REQUIREMENT AS DIRECTED BY ARCHITECT/ENGINEER.
C. SEE THE ARCHITECTURAL DRAWINGS FOR DOORS, WINDOWS, NON-BEARING INTERIOR AND EXTERIOR WALLS, RECESSES, DEPRESSIONS, ETC.
D. CONTRACTOR SHALL PROVIDE ADEQUATE TEMPORARY BRACING FOR ALL PORTIONS OF THE BUILDING UNTIL THE ENTIRE STRUCTURE OF THE BUILDING IS COMPLETE.
E. OBSERVATION VISITS TO THE SITE BY STRUCTURAL ENGINEER'S FIELD REPRESENTATIVES SHALL NOT BE CONSTRUED AS INSPECTION OR APPROVAL OF CONSTRUCTION.
F. ANY ENGINEERING DESIGN PROVIDED BY OTHERS AND SUBMITTED FOR REVIEW SHALL BEAR THE SEAL AND SIGNATURE OF A STRUCTURAL ENGINEER REGISTERED IN UTAH.

II. DESIGN CRITERIA:

A. BUILDING CODE: 2003 INTERNATIONAL BUILDING CODE (IBC) W/ AMENDMENTS
B. LOADINGS:

1. ROOF SNOW LOAD = 30 PSF + SNOW DRIFT PER IBC
2. TYPICAL FLOOR LIVE LOAD = 100 PSF
3. WIND LOAD – 90 MPH ZONE – EXPOSURE C
4. SEISMIC DESIGN CATEGORY: D

C. FOUNDATION:

1. ALL EXTERIOR FOOTINGS ARE TO BE FOUNDED AT NOT LESS THAN 30" BELOW LOWEST ADJACENT FINISH FLOOR OR FINISH GRADE ONTO UNDISTURBED EXISTING SUBSOILS HAVING A MINIMUM NET BEARING CAPACITY OF 1500 PSF. ALL INTERIOR FOOTINGS ARE TO BE FOUNDED AT NOT LESS THAN 1'-0" BELOW LOWEST ADJACENT FINISH FLOOR ONTO SUBSOILS.

III. CONCRETE:

A. ALL MATERIALS SHALL COMPLY WITH ACI 318 AND ACI 347 PUBLICATIONS AND APPLICABLE ASTM PUBLICATIONS.
B. CONCRETE MATERIAL PROPERTIES: 28-DAY COMPRESSIVE STRENGTHS ARE TO BE 3000 PSI TYPICAL UNLESS NOTED OTHERWISE. DESIGN BASED ON 2500 PSI.
C. CAST IN PLACE CONCRETE:

1. SPACING OF CONSTRUCTION JOINTS OR CONTROL JOINTS IN WALLS EXPOSED TO VIEW SHALL NOT EXCEED 40 FEET UNLESS SPECIFICALLY NOTED OTHERWISE ON THE DRAWINGS.
2. PROVIDE EXTRA REINFORCING AROUND ALL OPENINGS EXCEEDING 24 INCHES SQUARE OR ROUND IN ALL SLABS AND WALLS EQUAL TO TWO #5 BARS ON FOUR SIDES AND EXTEND TWO FEET BEYOND THE OPENING.
3. PROVIDE A 3/4" CHAMFER ON ALL EXPOSED CORNERS OF CONCRETE UNLESS NOTED OTHERWISE.
4. PROVIDE CLASS B LAP SPLICES FOR ALL REINFORCING UNLESS NOTED OTHERWISE.
5. PROVIDE ISOLATION JOINTS AROUND ALL COLUMNS AT ALL EXPOSED SLAB ON GRADE AREAS.

IV. REINFORCING STEEL:

A. ALL BARS #4 AND LARGER TO BE ASTM A 615, GRADE 60. ALL #2 AND #3 BARS TO BE ASTM A 615, GRADE 40. DETAILED, FABRICATED AND ERECTED IN ACCORDANCE WITH ACI-318, LATEST ADOPTION.
B. ALL REINFORCING STEEL SHALL BE BENT, DETAILED AND CHAIRED AS PER "ACI MANUAL OF STANDARD PRACTICE FOR DETAILING REINFORCING CONCRETE STRUCTURES".
C. WELDED WIRE FABRIC TO BE IN ACCORDANCE WITH ASTM A 185.
D. ALL BARS INDICATED ON THE PLANS TO BE WELDED SHALL CONFORM TO ASTM A706 (GRADE 60).
E. CONCRETE COVER REQUIREMENTS FOR DEFORMED BAR REINFORCING STEEL SHALL COMPLY WITH ACI 318, "BUILDING CODE REQUIREMENTS FOR REINFORCING CONCRETE".

1. CAST-IN-PLACE CONCRETE:

a) CONCRETE CAST AGAINST AND PERMANENTLY EXPOSED TO EARTH: 3"
b) FORMED CONCRETE EXPOSED TO EARTH OR WEATHER:

#6 BARS AND LARGER: 2"
#5 BARS AND SMALLER: 1-1/2"

c) CONCRETE NOT EXPOSED TO WEATHER OR IN CONTACT WITH GROUND:
SLABS, WALLS JOISTS: #11 BARS OR SMALLER: 3/4"
BEAMS, COLUMNS: PRIMARY REINFORCING, TIES, STIRRUPS, SPIRALS: 1-1/2"

F. DETAILING: SUBMIT PLACING DRAWINGS PER ACI DETAILING MANUAL, ACI SP-66. FABRICATE ONLY AFTER REVIEW AND APPROVAL. REINFORCING BARS SHALL NOT BE WELDED UNLESS SPECIFICALLY SHOWN ON DRAWINGS.

1. LAP SPLICE LENGTHS SHALL BE AS FOLLOWS:
30 BAR DIAMETER FOR #3 AND #4 BARS
40 BAR DIAMETER FOR #5 THROUGH #8 BARS
DO NOT SPLICE STIRRUPS AND TIES
DO NOT SPLICE VERTICAL BARS IN RETAINING WALLS UNLESS SPECIFICALLY SHOWN.
2. ALL EMBEDMENTS AND DOWELS SHALL BE SECURELY TIED TO FORMWORK OR TO ADJACENT REINFORCING PRIOR TO THE PLACEMENT OF CONCRETE.

V. STRUCTURAL AND MISCELLANEOUS STEEL:

A. MATERIAL PROPERTIES:

1. ALL SHAPES, PLATES, ANGLES, AND CHANNELS TO BE ASTM A-36 UNLESS NOTED OTHERWISE.
2. ALL WF SHAPES WEIGHING 84 POUNDS PER LINEAR FOOT OR LESS TO BE ASTM A 572, GRADE 50. ALL WF SHAPES WEIGHING MORE THAN 84 POUNDS PER LINEAR FOOT TO BE ASTM A 572, GRADE 36.
3. SQUARE OR RECTANGULAR TUBES TO BE ASTM A 500, GRADE B, Fy = 46 KSI.
4. ALL STEEL TO BE DETAILED, FABRICATED AND ERECTED IN ACCORDANCE WITH A.I.S.C. SPECIFICATIONS, LATEST ADOPTION.

B. WELDING:

1. FOR STRUCTURAL STEEL TO BE IN ACCORDANCE WITH A.W.S. REQUIREMENTS FOR E70XX ELECTRODES.

C. BOLTS:

1. ALL BOLTS TO BE 3/4" DIAMETER ASTM A 325-N UNLESS NOTED OTHERWISE.
2. BOLTS, NUTS AND WASHERS SHALL NOT BE REUSED.
3. ANCHOR BOLTS SHALL BE ASTM A 307 OR A 36.

VI. WOOD:

A. DIMENSIONAL LUMBER: ALL TO BE GRADE STAMPED PER W.C.L.B. RULES.

1. ALL JOISTS, BEAMS, PLATES, HEADERS AND OTHER LUMBER TO BE D.FIR/LARCH #2 UNLESS OTHERWISE NOTED.
2. 2 X 4 SUB-PURLINS TO BE D.FIR/LARCH NO.1.
3. 2X 6 SUB-PURLINS TO BE D.FIR/LARCH NO.1.
4. PURLINS TO BE D.FIR DENSE #1.
5. 4X AND 6X POSTS TO BE D.FIR/LARCH NO.1.
6. WALL STUDS TO BE D.FIR/LARCH #2 GRADE OR BETTER.

B. WOOD DECKING: FLOOR DECKING SHALL BE COMMERCIAL 2 X 6 (NOMINAL TONGUE AND GROOVE DECKING, HEM-FIR OR BETTER WITH A REPETITIVE Fb OF 1450 PSI MINIMUM.

C. GLU-LAMS:

1. TO BE GRADE STAMPED PER A.I.T.C., D.FIR/LARCH COMBINATION 24F-V8 FOR CONTINUOUS SPANS AND D.FIR/LARCH COMBINATION 24F-V4 FOR SIMPLE SPANS. GLUED WITH WATERPROOF GLUE.

D. PLYWOOD:

1. FLOOR SHEATHING TO BE STD 3/4" OSB OR C-C T&G WITH EXTERIOR GLUE, IDENTIFICATION INDEX 40/20. NAIL WITH 8d NAILS AT 6" O.C. AT ALL EDGE SUPPORTS AND WITH 8d NAILS AT 12" O.C. AT ALL INTERMEDIATE SUPPORTS UNLESS NOTED OTHERWISE.

E. PLYWOOD WEB I JOISTS:

1. TO BE DESIGNED, DETAILED AND FABRICATED BY TRUS-JOIST AND HAVE THE APPROVAL OF ICBO.
2. JOISTS ARE TO BE DESIGNED FOR THE LIVE LOADS LISTED ABOVE AND FOR A SUPERIMPOSED DEAD LOAD OF NOT LESS THAN 15 PSF.
3. DESIGN JOISTS FOR TWICE THE WEIGHT OF MECHANICAL UNITS INDICATED ON THE PLANS IN ACCORDANCE WITH AMERICAN INSTITUTE OF TIMBER CONSTRUCTION TECHNICAL NOTE #9. REVIEW ARCHITECTURAL AND MECHANICAL DRAWINGS FOR ADDITIONAL UNITS REQUIRED.

F. SPECIAL TREATMENTS (AMERICAN WOOD PRESERVERS INSTITUTE STANDARDS):

1. ALL WOOD IN CONTACT WITH CONCRETE, MASONRY OR SOIL: PRESSURE TREAT WITH WOLMAN CCA PRESERVATIVE OR EQUAL AS APPROVED BY THE ARCHITECT.
2. FIRE RETARDANT: PRESSURE TREAT WITH DRICON OR EQUAL AS APPROVED THE ARCHITECT.

G. WOOD NAILING SCHEDULE:

1. JOIST TO SILL OR GIRDER, TOENAIL 3-8d
2. BRIDGING TO JOIST, TOENAIL EACH END 2-8d
3. 1"X6" SUBFLOOR OR LESS TO EACH JOIST FACE NAIL 2-8d
4. WIDER THAN 1"X6" SUBFLOOR TO EACH JOIST, FACE NAIL 3-8d
5. SUBFLOOR TO JOIST OR GIRDER, BLIND AND FACE NAIL 2-16d
6. SOLE PLATE TO JOIST OR BLOCKING, FACE NAIL 2-16d
7. TOP PLATE TO STUD, END NAIL 2-16d
8. STUD TO SOLE PLATE TOENAIL 4-8d OR FACE NAIL 2-16d
9. DOUBLE STUDS, FACE NAIL 16d @ 24" o.c.
10. DOUBLED TOP PLATES, FACE NAIL 16d @ 16" O.C.
11. TOP PLATES, LAPS AND INTERSECTIONS, FACE NAIL 2-16d
12. CONTINUOUS HEADER, 2 PIECES 16d @ 16"O.C. ALONG 2 EDGES
13. CEILING JOISTS TO PLATE, TOENAIL 3-8d
14. CONTINUOUS HEADER TO STUD, TOENAIL 4-8d
15. CEILING JOIST, LAPS OVER PARTITIONS FACE NAIL 3-16d
16. CEILING JOIST TO PARALLEL RAFTERS FACE NAIL 3-16d
17. RAFTER TO PLATE, TOENAIL 4-8d
18. BRACE TO EACH STUD AND PLATE, FACE NAIL 2-8d
19. 1"X8" SHEATHING OR LESS TO EACH BEARING, FACE NAIL 2-8d
20. WIDER THAN 1"X8" SHEATHING TO EACH BEARING, FACE NAIL 3-8d
21. BUILT UP CORNER STUDS 16d @ 24" O.C.
22. BUILT-UP GIRDERS AND BEAMS 20d @ 32"O.C. AT TOP AND BOTTOM AND STAGGERED 2-20d AT EACH END & SPLICE
23. PLANKS 2-16d AT EACH BEARING

VII. MISCELLANEOUS:

A. GYPSUM WALLBOARD: FOR SHEAR WALLS TO BE STANDARD 1/2" GYPSUM WALLBOARD. NAIL WITH 5D COOLER NAILS AT 7" O.C. TO ALL STUDS, TOP AND BOTTOM PLATES AND BLOCKING.
B. STUCCO: FOR SHEAR WALLS TO BE STANDARD 7/8" PORTLAND CEMENT PLASTER ON EXPANDED METAL OR WOVEN WIRE LATH. NAIL WITH NO.11 GAGE, 1 1/2" LONG, 7/16" HEAD NAILS OR NO.16 GAGE STAPLES WITH 7/8" LONG LEGS AT 6" O.C. TO ALL STUDS, TOP AND BOTTOM PLATES AND BLOCKING.

VIII. SPECIAL INSPECTION: SPECIAL INSPECTION IS REQUIRED IN ACCORDANCE WITH IBC SECTION 1701.

A. FIELD WELDING IF APPLY.
B. LEVEL TWO INSPECTION ON CMU UNITS.

IX. MASONRY:

A. GENERAL:

1. LIGHTWEIGHT HOLLOW CONCRETE MASONRY UNIT TO BE ASTM C 90, GRADE N-1 AND HAVE A MINIMUM UNIT STRENGTH OF 2800 PSI AND f'm OF 2000 PSI. MORTAR TO BE TYPE "S". GROUT FILL TO BE 2000 PSI AT 28 DAYS.
2. MASONRY DESIGN IS BASED ON VALUES WITH LEVEL 2 INSPECTION.
3. SEE CONCRETE FOR REQUIREMENTS FOR REINFORCING.

B. MASONRY REINFORCING:

1. MINIMUM REINFORCING OF CONCRETE MASONRY UNIT WALLS:
ALL MASONRY WALLS SHALL BE REINFORCING AS FOLLOWS, UNLESS SHOWN OTHERWISE ON THE DRAWINGS
2. C.M.U. WALLS ARE TO HAVE #5 VERTICALS AT ALL CORNERS, ENDS, JAMBS, INTERSECTIONS AND BOTH SIDES OF CONTROL JOINTS, TYPICAL UNLESS NOTED OTHERWISE.
3. ADDITIONAL VERTICAL REINFORCING SHOWN ON PLAN IS IN LIEU OF TYPICAL REINFORCING. PLACE ONE BAR PER CELL IN SOLID GROUT. EXTEND BARS A MINIMUM OF 30 BAR DIAMETERS BEYOND THE ROOF LEVEL ABOVE.
4. BUILDING WALLS ARE TO HAVE 2 #5 BARS CONTINUOUS IN A MINIMUM 8" DEEP BOND BEAM AT ALL ROOF LEVELS UNLESS NOTED OTHERWISE.
5. BUILDING WALLS ARE TO HAVE 1 #5 BAR CONTINUOUS IN A MINIMUM 8" DEEP BOND BEAM AT THE TOP OF ALL PARAPETS UNLESS NOTED OTHERWISE.
6. PROVIDE A MINIMUM OF 2 #5 BARS X (THE WIDTH OF THE OPENING PLUS 4'-0") IN A MINIMUM 8" DEEP BOND BEAM BELOW ALL WINDOW AND MECHANICAL OPENINGS UNLESS NOTED OTHERWISE.

C. MASONRY LINTELS:

1. ALL REINFORCING IS TO EXTEND A MINIMUM OF 2'-0" BEYOND THE JAMB AND TO BE GROUTED SOLID FOR THE ENTIRE DEPTH INDICATED.
2. ALL CONCRETE MASONRY UNITS USED IN THE LENGTH ARE TO BE "OPEN-END" TYPE, TO INSURE FULLY GROUTED HEAD JOINTS.
3. ALL LINTELS ARE TO BE PROPERLY SHORED FOR THEIR WEIGHT PLUS ANY CONSTRUCTION LOADS AND LATERALLY BRACED TO PREVENT ANY LATERAL MOVEMENT FOR A MINIMUM OF 7 DAYS AFTER GROUTING, UNLESS NOTED OTHERWISE.

D. MASONRY GROUTING PROCEDURES:

1. GROUTED MASONRY SHALL BE CONSTRUCTED IN SUCH A MANNER THAT ALL ELEMENTS OF THE MASONRY ACT TOGETHER AS A STRUCTURAL ELEMENT.
2. PRIOR TO GROUTING, THE GROUT SPACE SHALL BE CLEANED SO THAT ALL SPACES TO BE FILLED WITH GROUT DO NOT CONTAIN MORTAR PROJECTIONS GREATER THAN 1/2", MORTAR DROPPINGS OR OTHER FOREIGN MATERIAL.
3. GROUT MATERIALS AND WATER CONTENT SHALL BE CONTROLLED TO PROVIDE ADEQUATE FLUIDITY FOR PLACEMENT, WITHOUT SEGREGATION OF THE CONSTITUENTS AND SHALL BE MIXED THOROUGHLY. SEGREGATION OF THE GROUT MATERIALS AND DAMAGE TO THE MASONRY SHALL BE AVOIDED DURING THE GROUTING PROCESS.
4. THE GROUTING OF ANY SECTION OF WALL SHALL BE COMPLETED IN ONE DAY WITH NO INTERRUPTIONS GREATER THAN ONE HOUR.
5. BETWEEN GROUT POURS, A HORIZONTAL CONSTRUCTION JOINT SHALL BE FORMED BY STOPPING ALL WYTHES AT THE SAME ELEVATION AND WITH THE GROUT STOPPING A MINIMUM OF 1 1/2 INCHES BELOW A MORTAR JOINT, EXCEPT AT THE TOP OF THE WALL. WHERE BOND BEAMS OCCUR, STOP GROUT POUR A MINIMUM OF 1/2 INCH BELOW THE TOP OF THE MASONRY.
6. ALL CELLS AND SPACES CONTAINING REINFORCING BARS SHALL BE FILLED WITH GROUT. GROUT SHALL BE PLACED SO THAT ALL SPACES TO BE GROUTED DO NOT CONTAIN VOIDS.
7. GROUT SHALL BE CONSOLIDATED BY MECHANICAL VIBRATION DURING PLACING BEFORE LOSS OF PLASTICITY IN A MANNER TO FILL THE GROUT SPACE. GROUT POURS GREATER THAN 12 INCHES SHALL BE RECONSOLIDATED BY MECHANICAL VIBRATION TO MINIMIZE VOIDS DUE TO WATER LOSS. GROUT POURS 12 INCHES OR LESS IN HEIGHT SHALL BE MECHANICALLY VIBRATED, OR PUDDLED.
8. WHERE GROUT POURS EXCEED 5 FEET, CLEANOUTS SHALL BE PROVIDED IN THE BOTTOM COURSE AT EVERY VERTICAL BAR LOCATION BUT SHALL NOT BE SPACED MORE THAN 32 INCHES ON CENTER FOR SOLID GROUTED MASONRY. GROUT SHALL BE PLACED IN A CONTINUOUS POUR NOT TO EXCEED 16 FEET IN HEIGHT, AND IN GROUT LIFTS NOT TO EXCEED 6 FEET.
9. REINFORCING SHALL BE CONTINUOUS THE FULL HEIGHT OF THE GROUT POUR PLUS ANY REQUIRED LAP ABOVE. REINFORCEMENT SHALL BE SECURED AGAINST DISPLACE MENT PRIOR TO GROUTING BY WIRE POSITIONERS OR OTHER SUITABLE DEVICES AT INTERVALS NOT TO EXCEED 200 BAR DIAMETERS NOR 10 FEET.
10. TOLERANCE FOR THE PLACEMENT OF STEEL IN WALLS AND FLEXURAL ELEMENTS SHALL BE PLUS OR MINUS 1/2 INCH FOR "D" EQUAL TO 8 INCHES OR LESS, PLUS OR MINUS ONE INCH FOR "D" EQUAL TO 24 INCHES OR LESS BUT GREATER THAN 8 INCHES, AND PLUS OR MINUS 1 1/4 INCH FOR "D" GREATER THAN 24 INCHES.



NOTE: THREADED INSERT MAY BE USED IN LIEU OF DOWEL

4 INTERIOR CMU WALL & FOOTING



1



2



3

State of Utah
Department of Administrative Services
Division of Facilities Construction & Management
4110 State Office Building
Salt Lake City, Utah 84114
Phone: (801) 538 - 3018
Fax: (801) 538 - 3267
Internet: http://www.dfcm.state.ut.us

CREATED BY: P+A architects

P+A architects
821 East Kensington Ave.
Salt Lake City, Utah 84105
P: 801.484.1161
F: 801.485.4640
e-mail parchitects@comcast.net
ARCHITECTURE PLANNING DESIGN

BUILDING NAME:
UINTAH BASIN APPLIED TECH. COLLEGE

LICENSED PROFESSIONAL ENGINEER No. 260129 HUA SHEN STATE OF UTAH

PROJECT TITLE:
UINTAH BASIN APPLIED TECH. COLLEGE PAINT BOOTH REMODEL

Shen Engineers, Inc.
Structural/Seismic Consultants
3335 South 900 East, Suite 250
Salt Lake City, UT 84106
Telephone 801 466-2625
Facsimile 801 466-2656
E-mail: sheneng@msn.com

MARK	DATE	DESCRIPTION

ISSUE TYPE: CONSTRUCTION DOCUMENTS
ISSUE DATE: AUG. 1, 2005
DFCM PROJECT NO:
CAD PROJECT NO: SE05173
CAD DWG FILE:
DRAWN BY: BS
CHK'D BY: HS

SHEET TITLE
SHEET NUMBER
S-GN100
SHEET 8 OF 15

AutoCAD Version: 13_c4
April 08, 1996 3:28:37 p.m.
Drawing: C:\R13\COM\PROTOS\D12.DWG (RJG)

FLOOR FRAMING PLAN NOTES:

1. SEE TYPICAL DETAIL SHEET FOR:
   A. GENERAL STRUCTURAL NOTES
2. HANGING CEILING, DUCTWORK OR OTHER ITEMS FROM THE ROOF METAL DECK IS NOT ALLOWED.
3. PROVIDE JOIST BRIDGING PER S.J.I.
4. ESTABLISH AND VERIFY ALL OPENINGS & INSERTS FOR MECHANICAL, ELECTRICAL & PLUMBING WITH THE APPROPRIATE TRADES, DRAWINGS AND SUBCONTRACTORS PRIOR TO CONSTRUCTION.
5. JOIST & JOIST GIRDER DESIGNATIONS DO NOT INCLUDE MECHANICAL WEIGHTS. DESIGN JOISTS & JOIST GIRDERS @ MECH. UNITS TO SUPPORT WEIGHTS INDICATED @ ANY POINT WITHIN 5 FEET EITHER WAY ALONG THE SPAN.
6. JOIST MANUF. TO ADJUST ALL JOIST SIZES AND DESIGN STRESSES AS REQUIRED BASED ON THE SPECIFIC UL RATING NOTED ON THE ARCHITECTURAL DRAWINGS.

MASONRY PIER SCHEDULE

MARK	SIZE	REINF.	TIES	MIN. BRG. PL SIZE FOR BM./GIRDER
MP-1	8" x 8"	(2) #5	NONE	1/2"x7"x7" PL. w/ (1) 3/4"ø H.S. x5"
MP-2	8" x 16"	(4) #5	#2 @ 8" O.C.	1/2"x7"x14" PL. w/ (2) 3/4"ø H.S. x5"

MARK	SIZE OF LINTEL	REINFORCING	MIN. END BRG.	REMARKS
ML-1	8"x8"	(2) #5	MP-1	

FOUNDATION PLAN NOTES:

1. SEE GENERAL STRUCTURAL NOTES SHEET AND STANDARD CONCRETE DETAIL SHEET FOR
   A. GENERAL STRUCTURAL NOTES
   B. TYPICAL EXCAVATION ADJACENT TO FOOTING
   C. TYPICAL SLAB JOINT DETAILS
   D. TYPICAL STEPPED FOOTING
2. WS – DENOTES CONCRETE WALL STEP.
3. F-1 – DENOTES FOOTING MARK – SEE FOOTING SCHEDULE.
4. K.C.J. – DENOTES KEYED CONSTR. JOINT – SEE STANDARD DETAIL.
5. C.J. – DENOTES CONTROL JOINT – SEE STANDARD DETAIL.
6. F-----S – DENOTES FOOTING STEP, SEE DETAIL TYPICAL.
7. CONTRACTOR TO VERIFY ALL DIMENSIONS AND ELEVATIONS WITH ARCHITECTURAL DRAWINGS PRIOR TO CONSTRUCTION. SEE ARCHITECTURAL FOR ALL DIMENSIONS, SLAB SLOPES & DEPRESSIONS NOT NOTED.
8. ALL SLABS ON GRADE ARE TO BE JOINTED AT NO MORE THAN 15'-0" EACH WAY USING JOINTS AS PER STANDARD DETAIL. IN ADDITION, NO SECTION OF CONCRETE SHALL HAVE AN ASPECT RATIO OF GREATER THAN 1 1/2:1. PROVIDE (2) #4 x 4'-0" MID-HEIGHT SLAB BARS ADJACENT TO ALL DISCONTINUOUS JOINT LOCATIONS. ALL COLUMN ISOLATION JOINT CORNERS ARE TO BE INTERSECTED BY A SLAB JOINT OR REINFORCED WITH SLAB BARS PER ABOVE. SUBMIT COMPLETE JOINT LAYOUT PLAN TO THE ARCHITECT FOR PRIOR REVIEW.

TYPICAL FLOOR DECK:

3/4" APA RATED SHEATHING, SPAN RATING 40/20
SEE GENERAL STRUCTURAL NOTES-TYPICAL NAILING:
8d @ 6" O.C. AT ALL PANEL EDGES, SUPPORTED EDGES, AND ALL TOP OF SHEAR WALLS
8d @ 12" O.C. AT ALL PANEL FIELD
PLACE SHEATHING LONG-WISE ACROSS FRAMING, STAGGER END JOINTS. UNBLOCKED DIAPHRAGM.

PROVIDE 8x16 BOND BEAM w/(4)#5 HORIZ. CONT. AT FLOOR LEVEL TYP. U.N.O.



PLAN NORTH

NEW FLOOR FRAMING PLAN
SCALE 1/4" = 1'-0"



PLAN NORTH

NEW FOUNDATION PLAN
SCALE 1/4" = 1'-0"

MASONRY WALL SCHEDULE

LEVEL II SPECIAL INSPECTION ON CMU TYP.
F'm=2000 PSI

MARK	WALL THICKNESS	VERT. REINF.	HORIZ. REINF.	BOND BM. @ ROOF LVL	REMARKS
MW1	8"	#5 @ 32" O.C.	#5 @ 48" O.C.	8"x16" MIN. w/ (4)#5 HORIZ.	GROUT CELLS w/REBARS. TYP. FOR 8" CMU WALLS U.N.O.

1. TERMINATE HORIZ. REBARS AT WALL JOINTS TYP.
2. CONTINUE HORIZ. REBARS FOR BOND BEAM AT WALL JOINTS TYP.
3. SOLID GROUT ALL CELLS FOR WALLS UNDER FINISHED GRADE TYP.

AutoCAD Version: 13_c4
April 08, 1996 3:28:37 p.m.
Drawing: C:\R13\COM\PROTOS\D12.DWG (RJG)

State of Utah
Department of Administrative Services

Division of Facilities Construction & Management
4110 State Office Building
Salt Lake City, Utah 84114
Phone: (801) 538 - 3018
Fax: (801) 538 - 3267

Internet: http://www.dfcm.state.ut.us

CREATED BY: P+A architects

P+A architects
821 East Kensington Ave.
Salt Lake City, Utah 84105
P: 801.484.1161
F: 801.485.4640
e-mail parchitects@comcast.net

ARCHITECTURE | PLANNING | DESIGN

BUILDING NAME:

UINTAH BASIN APPLIED TECH. COLLEGE

LICENSED PROFESSIONAL ENGINEER
No. 260129
HUA SHEN
STATE OF UTAH

PROJECT TITLE:

UINTAH BASIN APPLIED TECH. COLLEGE PAINT BOOTH REMODEL

Shen Engineers, Inc.
Structural/Seismic Consultants
3335 South 900 East, Suite 250
Salt Lake City, UT 84106
Telephone 801 466-2625
Facsimile 801 466-2656
E-mail: sheneng@msn.com

MARK	DATE	DESCRIPTION

ISSUE TYPE: CONSTRUCTION DOCUMENTS

ISSUE DATE: AUG. 1, 2005

DFCM PROJECT NO:
CAD PROJECT NO: SE05173
CAD DWG FILE:
DRAWN BY: BS
CHK'D BY: HS

SHEET TITLE

SHEET NUMBER

S-FP101



A3 ROOF FRAMING PLAN TO SUPPORT NEW "MAU"

SCALE: 1/4" = 1'-0"



1 NEW OPENING IN C.M.U. WALL

State of Utah
Department of Administrative Services
Division of Facilities Construction & Management
4110 State Office Building
Salt Lake City, Utah 84114
Phone: (801) 538 - 3018
Fax: (801) 538 - 3267
Internet: http://www.dfcm.state.ut.us

CREATED BY: P+A architects

P+A architects
821 East Kensington Ave.
Salt Lake City, Utah 84105
P: 801.484.1161
F: 801.485.4640
e-mail parchitects@comcast.net
ARCHITECTURE PLANNING DESIGN

BUILDING NAME:

UINTAH BASIN APPLIED TECH. COLLEGE

LICENSED PROFESSIONAL ENGINEER No. 260129 HUA SHEN STATE OF UTAH

PROJECT TITLE:

UINTAH BASIN APPLIED TECH. COLLEGE PAINT BOOTH REMODEL

Shen Engineers, Inc.
Structural/Seismic Consultants
3335 South 900 East, Suite 250
Salt Lake City, UT 84106
Telephone 801 466-2625
Facsimile 801 466-2656
E-mail: sheneng@msn.com

MARK	DATE	DESCRIPTION

ISSUE TYPE: CONSTRUCTION DOCUMENTS

ISSUE DATE: AUG. 1, 2005

DFCM PROJECT NO:
CAD PROJECT NO: SE05173
CAD DWG FILE:
DRAWN BY: BS
CHK'D BY: HS

SHEET TITLE

SHEET NUMBER

S-FP102

AutoCAD Version: 13_c4
April 08, 1996 3:28:37 p.m.
Drawing: C:\R13\COM\PROTOS\D12.DWG (RJG)

D



10



7 MASONRY PIER CONFIGURATION



4 TYP. REINF. @ CORNER OR INTERSECTION OF WALLS



1 TYPICAL CONCRETE FLOOR JOINTS

C



B

11



8 TYPICAL NEW FTG. TO EXIST. FTG. CONN.



5 TYPICAL MASONRY WALL OPNG. REINF.



NOTE: ALL BENDS SHALL BE MADE COLD.

2 TYPICAL REINFORCING BAR BENDS



A

12 TYPICAL WOOD BEAM-CMU WALL CONN.



9

MARK	REINFORCING	GROUT "D"
ML-1	(2) #5	8"
ML-2	(2) #5 T. & B.	12"
ML-3	(2) #5 T. 7 B.	20"

ALL REINFORCING TO EXTEND A MINIMUM OF 2'-0" BEYOND JAMBS AND BE GROUTED SOLID FOR DEPTH "D".

ALL CONCRETE MASONRY UNITS USED IN LENGTH OF LINTEL TO BE "OPEN-END" TYPE, TO INSURE FULLY GROUTED HEAD JOINTS.

ALL LINTELS TO BE PROPERLY SHORED DURING GROUTING AND REMAIN IN PLACE FOR A MINIMUM OF 7 DAYS FOLLOWING GROUTING.

ALL GROUT TO BE MINIMUM OF 2000 PSI AT 28 DAYS.



LINTEL SECTION

6 MASONRY LINTEL SCHEDULE



NOTE: CONCRETE FILL TO BE THE SAME WIDTH AS FOOTING & FULL WIDTH OF PIPE TRENCH. PIPE TO CLEAR SLEEVE BY 1/2" ALL AROUND

3 PIPES AT CONCRETE FOOTING IF APPLY

State of Utah
Department of Administrative Services
Division of Facilities Construction & Management
4110 State Office Building
Salt Lake City, Utah 84114
Phone: (801) 538 - 3018
Fax: (801) 538 - 3267
Internet: http://www.dfcm.state.ut.us

CREATED BY: P+A architects

P+A architects
821 East Kensington Ave.
Salt Lake City, Utah 84105
P: 801.484.1161
F: 801.485.4640
e-mail parchitects@comcast.net
ARCHITECTURE PLANNING DESIGN

BUILDING NAME:

UINTAH BASIN APPLIED TECH. COLLEGE

LICENSED PROFESSIONAL ENGINEER No. 260129 HUA SHEN STATE OF UTAH

PROJECT TITLE:

UINTAH BASIN APPLIED TECH. COLLEGE PAINT BOOTH REMODEL

Shen Engineers, Inc.
Structural/Seismic Consultants
3335 South 900 East, Suite 250
Salt Lake City, UT 84106
Telephone 801 466-2625
Facsimile 801 466-2656
E-mail: sheneng@msn.com

MARK	DATE	DESCRIPTION

ISSUE TYPE: CONSTRUCTION DOCUMENTS

ISSUE DATE: AUG. 1, 2005

DFCM PROJECT NO:
CAD PROJECT NO: SE05173
CAD DWG FILE:
DRAWN BY: BS
CHK'D BY: HS

SHEET TITLE

SHEET NUMBER

S-SD501

AutoCAD Version: 13_c4
April 08, 1996 3:28:37 p.m.
Drawing: C:\R13\COM\PROTOS\D12.DWG (RJG)

SYMBOL LEGEND

SYMBOL	DESCRIPTION
PLUMBING PIPING	
—CWV—	COMBINATION WASTE AND VENT
	SOIL, WASTE – ABOVE GRADE
	SOIL, WASTE – BELOW GRADE
—GW—	GREASE WASTE – ABOVE GRADE
—GW—	GREASE WASTE – BELOW GRADE
	VENT
—AV—	ACID VENT
—AW—	ACID WASTE – ABOVE GRADE
—AW—	ACID WASTE – BELOW GRADE
	COLD WATER
	HOT WATER
	HOT WATER CIRCULATE
—180—	180°F HOT WATER
—180R—	180° HOT WATER RETURN
—160—	160° HOT WATER
—160R—	160° HOT WATER RETURN
—RW—	RAINWATER – ABOVE GRADE
—RW—	RAINWATER – BELOW GRADE
—ORW—	OVERFLOW RAINWATER ABOVE GRADE
—ORW—	OVERFLOW RAINWATER BELOW GRADE
—SD—	STORM DRAIN
VTR	VENT THRU ROOF
	NON POTABLE WATER
(E)	EXISTING PIPE
(E)	EXISTING PIPE TO BE REMOVED
—IW—	IRRIGATION WATER
—SS—	SANITARY SEWER
—W—	WATER
—PWS—	PURE WATER SUPPLY
—PWR—	PURE WATER RETURN
—G—	GAS
—LPG—	PROPANE
—VAC—	VACUUM
—A—	COMPRESSED AIR
—MA—	MEDICAL AIR
—O—	OXYGEN
—NO—	NITROUS OXIDE
—N—	NITROGEN
—CO2—	CARBON DIOXIDE
—EVAC—	EVACUATION

SYMBOL LEGEND

SYMBOL	DESCRIPTION
HVAC PIPING	
—HPS—	HIGH PRESSURE STEAM
—MPS—	MEDIUM PRESSURE STEAM
—LPS—	LOW PRESSURE STEAM
—HPC—	HIGH PRESSURE RETURN
—MPC—	MEDIUM PRESSURE RETURN
—LPC—	LOW PRESSURE RETURN
—PC—	PUMP DISCHARGE
—HWS—	HOT WATER SUPPLY
—HWR—	HOT WATER RETURN
—TWS—	TEMPERED WATER SUPPLY
—CWS—	CHILLED WATER SUPPLY
—CWR—	CHILLED WATER RETURN
—RL—	REFRIGERANT LIQUID
—RS—	REFRIGERANT SUCTION
—D—	DRAIN LINE
—HG—	HOT GAS BYPASS
—GS—	GLYCOL SUPPLY
—GR—	GLYCOL RETURN
—FOS—	FUEL OIL SUCTION
—FOR—	FUEL OIL RETURN
—FOV—	FUEL OIL VENT
(E)	EXISTING PIPE
(E)	EXISTING PIPE TO BE REMOVED

ABBREVIATIONS

NOTE: ALL ABBREVIATIONS MAY NOT BE USED

AD	ACCESS DOOR	MCA	MINIMUM CIRCUIT AMPS
AIR COND	AIR CONDITION(–ING,–ED)	MFR	MANUFACTURER
APD	AIR PRESSURE DROP	MIN	MINIMUM
BD	BALANCING DAMPER	N/A	NOT APPLICABLE
BHP	BRAKE HORSE POWER	NC	NORMALLY CLOSED
BTU	BRITISH THERMAL UNIT	NIC	NOISE CRITERIA
BTUH	BTU/HOUR	NO	NOT IN CONTRACT
CFH	CUBIC FEET PER HOUR	NPSH	NORMALLY OPEN
CFM	CUBIC FEET PER MINUTE		NET POSITIVE SUCTION HEAD
CLG	COOLING	NTS	NOT TO SCALE
COMP	COMPONENT	OA	OUTSIDE AIR
COND	CONDENS(–ER, –ING, –ATION)	OD	OUTSIDE DIAMETER
		OZ	OUNCE
CV	CONTROL VALVE	PD	PRESSURE DROP OR DIFFERENCE
CW	COLD WATER		
DIA	DIAMETER	PG	PROPYLENE GLYCOL
DISCH	DISCHARGE	PH	PHASE
DP	DEPTH OR DEEP	PPM	PARTS PER MILLION
DB	DRY BULB TEMPERATURE	PRESS	PRESSURE
(E)	EXISTING	PSF	POUNDS PER SQUARE FOOT
EER	ENERGY EFFICIENCY RATIO		
EFF	EFFICIENCY	PSI	POUNDS PER SQUARE INCH
EG	ETHYLENE GLYCOL		
ELEC	ELECTRIC	PSIA	PSI ABSOLUTE
ELEV	ELEVATION	PSIG	PSI GAUGE
ENT	ENTERING	R	THERMAL RESISTANCE
EVAP	EVAPORAT(–E, –ING, –ED, –OR)	RA	RETURN AIR
		RECIRC	RECIRCULATE
EWT	ENTERING WATER TEMPERATURE	REFR	REFRIGERATION
		REQD	REQUIRED
EXT	EXTERNAL	RLA	RATED ––– AMPS
(F)	FUTURE	RPM	REVOLUTIONS PER MINUTE
F	FAHRENHEIT	RW	RAINWATER
FC	FLEXIBLE CONNECT(–OR, –ION)	SA	SUPPLY AIR
		SC	SHADING COEFFICIENT
FD	FIRE DAMPER	SCFM	STANDARD CUBIC FEET PER MINUTE
FLA	FULL LOAD AMPS		
FPI	FINS PER INCH	SCW	SOFT COLD WATER
FPM	FEET PER MINUTE	SF	SAFETY FACTOR
FPS	FEET PER SECOND	SH	SENSIBLE HEAT
FSD	FIRE SMOKE DAMPER	SL	SEA LEVEL
FT	FEET	SP	STATIC PRESSURE
GAL	GALLON(S)	SPECS(S)	SPECIFICATION(S)
GPH	GALLONS PER HOUR	SQ	SQUARE
GPM	GALLONS PER MINUTE	STD	STANDARD
HD	HEAD	STM	STEAM
HG	MERCURY	TEMP	TEMPERATURE
HR	HOUR	TD	TEMP. DROP OR DIFF.
HT	HEIGHT	THERM	THERMAL
HTG	HEATING	TOT	TOTAL
HP	HORSE POWER	TSTAT	THERMOSTAT
HW	HOT WATER	V	VOLT
HZ	HERTZ(FREQUENCY)	VAC	VACUUM
ID	INSIDE DIAMETER	VAV	VARIABLE AIR VOLUME
IN	INCH	VEL	VELOCITY
KW	KILOWATT	VENT	VENT, VENTILATION
LAT	LEAVING AIR TEMPERATURE	VERT	VERTICAL
		VFD	VARIABLE FREQUENCY DRIVE
LBS	POUNDS		
LG	LENGTH	VOL	VOLUME
LH	LATENT HEAT	WC	WATER COLUMN
LRA	LOCKED ROTOR AMPS	WG	WATER GAUGE
LVG	LEAVING	WPD	WATER PRESSURE DROP
LWT	LEAVING WATER TEMPERATURE	WTR	WATER
		WT	WEIGHT
MAX	MAXIMUM	WB	WET BULB TEMP
MBH	THOUSAND BTU PER HOUR	YR	YEAR

SYMBOL LEGEND

SYMBOL	DESCRIPTION
VALVES, METERS, AND GAUGES	
	SHUT OFF VALVE
	GATE VALVE
	CHECK VALVE
	AUTO 2–WAY VALVE
	AUTO 3–WAY VALVE
	GLOBE VALVE
	BALL VALVE
	RELIEF VALVE
	CHAIN OPERATED GATE VALVE
	PRESSURE REDUCING VALVE
	BUTTERFLY VALVE
	SOLENOID VALVE
	ANGLE VALVE
	VENTURI
	BALANCING OR PLUG COCK
	FLOW SETTER
	EXPANSION VALVE (REFRIG.)
	GAS COCK
MAV	MANUAL AIR VENT
	STRAINER
	GAUGE COCK
	FLEXIBLE CONNECTION
	PRESSURE GAUGE
	THERMOMETER
	VICTUALIC COUPLING
	REDUCER CONCENTRIC
	REDUCER ECCENTRIC
	REFRIGERANT SITE GLASS
	REFRIGERANT STAINER
	REFRIGERANT FILTER DRIER
	90° ELBOW UP
	90° ELBOW DOWN
	90° TEE UP
	90° TEE DOWN
	UNION
	CAPPED PIPE
	ANCHOR
	FLOAT AND THERMOSTATIC TRAP
HVAC SYMBOLS	
T	THERMOSTAT
S	TEMPERATURE SENSOR
H	HUMIDISTAT
PLUMBING SYMBOLS	
C.B.	CATCH BASIN
W.H.	WALL HYDRANT
H.B.	HOSE BIBB
	CLEANOUT TO GRADE
	FLOOR CLEANOUT
	WALL CLEANOUT
	1/2 GRATE
	3/4 GRATE
	FULL GRATE

SYMBOL LEGEND

SYMBOL	DESCRIPTION
DUCTWORK	

SINGLE LINE	DOUBLE LINE	DESCRIPTION
		RECTANGULAR SUPPLY DUCT UP
		RECTANGULAR SUPPLY DUCT DOWN
		RECTANGULAR RETURN DUCT UP
		RECTANGULAR RETURN DUCT DOWN
		RECTANGULAR EXHAUST DUCT UP
		RECTANGULAR EXHAUST DUCT DOWN
		ROUND DUCT UP
		ROUND DUCT DOWN
		ACCOUSTICALLY LINED RECTANGULAR DUCT
		90° RECTANGULAR ELBOW WITH TURNING VANES
		90° RADIUS ELBOW R=1.5
		DUCT SIZE OR SHAPE TRANSITION
		OPPOSED BLADE BALANDING DAMPER (O.B.D.) IN RECT DUCT
		BUTTERFLY BALANCING DAMPER IN ROUND DUCTS
		COMBINATION TEE
		SPLITTER DAMPER
		SQUARE OR RECTANGULAR CEILING DIFFUSER
		SIDEWALL REGISTER SUPPLY OR RETURN
		ROUND FLEXIBLE DUCT
		RETURN GRILLE
		EXHAUST GRILLE
FSD	FSD	FIRE/SMOKE DAMPER
		FIRE DAMPER
SD	SD	SMOKE DAMPER
FC	FC	FLEXIBLE CONNECTION
		EXISTING DUCT
		DUCT TO BE REMOVED

GENERAL MECHANICAL NOTES

1. DO NOT ROUTE DUCTS AND PIPES ABOVE ELECTRICAL PANELS. ALL ELECTRICAL PANELS MUST HAVE CLEAR ACCESS SPACE IN FRONT OF PANEL 4'–0" DEEP AND 6'–6" HIGH. DO NOT ROUTE DUCTS AND PIPES IN ELECTRICAL ROOMS, EXCEPT DUCTS AND PIPES SERVING THE ROOM.
2. IF CONTRACTOR ENCOUNTERS MATERIAL WHICH MAY CONTAIN ASBESTOS IMMEDIATELY STOP WORK IN THIS AREA AND NOTIFY THE OWNER.
3. PROVIDE CEILING ACCESS PANELS AS REQUIRED WHERE MECHANICAL EQUIPMENT, VALVES, VAV BOXES, FIRE DAM– PERS, ETC. ARE LOCATED ABOVE INACCESSIBLE CEILINGS.
4. STEEL ROOF DECK SHALL NOT BE USED TO SUPPORT LOADS FROM PIPING, DUCTWORK OR EQUIPMENT, UNLESS NOTED OTHERWISE. HANGER LOADS LESS THAN 50 LBS. MAY BE HUNG FROM THE STEEL ROOF DECK IN CASES WHEN HANGING FROM THE STEEL ROOF DECK CANNOT BE AVOIDED; THE ATTACHMENT METHOD MUST DISTRIBUTE THE LOAD ACROSS THE DECK AS APPROVED BY THE STRUCTURAL ENGINEER.

MECHANICAL SHEET INDEX

SYMBOL LEGEND

SYMBOL	DESCRIPTION
REFERENCE AND LINE SYMBOLS	
# / SHEET	DETAIL INDICATOR: # INDICATES DETAIL NUMBER, SHEET INDICATES DRAWING SHEET WHERE DETAIL IS SHOWN.
# / SHEET	ELEVATION OR SECTION INDICATOR, EXTERIOR: # INDICATES ELEVATION OR SECTION NUMBER, SHEET INDICATES DRAWING SHEET WHERE ELEVATION OR SECTION IS SHOWN.
# / SHEET	ELEVATION OR SECTION INDICATOR, INTERIOR: # INDICATES ELEVATION OR SECTION NUMBER, SHEET INDICATES DRAWING SHEET WHERE ELEVATION OR SECTION IS SHOWN.
100	ROOM OR SPACE NUMBER.
1	KEYNOTE INDICATOR.
	REVISION INDICATOR.
CU–1	EQUIPMENT INDICATOR.
P–	PLUMBING FIXTURE INDICATOR.
TYPE / CFM / SIZE	DIFFUSER/GRILLE INDICATOR.
TYPE / SIZE	DIFFUSER/GRILLE INDICATOR.
	BREAK, STRAIGHT
	BREAK, ROUND.
MATCH LINE / SEE XX/X–XXX	MATCH LINE INDICATOR
	HIDDEN FEATURES LINE: HIDDEN, THIN LINE.
	CONTRACT LIMIT LINE: DASHDOT, WIDE LINE.
	NEW CONNECTION POINT TO EXISTING

Registered Professional Engineer
STEVEN SHEPHERD
No. 189989
11.9.05
State of Utah

State of Utah
Department of Administrative Services
Division of Facilities Construction & Management
4110 State Office Building
Salt Lake City, Utah 84114
Phone: (801) 538 - 3018
Fax: (801) 538 - 3267
Internet: http://www.dfcm.state.ut.us

CREATED BY: P+A architects

P+A architects
821 East Kensington Ave.
Salt Lake City, Utah 84105
P: 801.484.1161
F: 801.485.4640
e-mail parchitects@comcast.net

ARCHITECTURE | PLANNING | DESIGN

BUILDING NAME:

UINTAH BASIN APPLIED TECH. COLLEGE

PROJECT TITLE:

UINTAH BASIN APPLIED TECH. COLLEGE PAINT BOOTH EXPANSION

MARK	DATE	DESCRIPTION

ISSUE TYPE: CONSTRUCTION DOCUMENTS

ISSUE DATE: NOVEMBER 09, 2005

DFCM PROJECT NO: 05078250
CAD PROJECT NO: 2005-11
CAD DWG FILE:
DRAWN BY: E. JUAREZ
CHK'D BY: S. SHEPHERD

SHEET TITLE

MECHANICAL GENERAL NOTES & SYMBOLS LEGEND

SHEET NUMBER

M-001

SHEET 12 OF 15



PLAN NORTH

A1 MECHANICAL DEMOLITION FLOOR PLAN

SCALE: 1/4" = 1'-0"



PLAN NORTH

A3 NEW MECHANICAL FLOOR PLAN

SCALE: 1/4" = 1'-0"

SHEET KEYNOTES

1. PROVIDE AND INSTALL VERTICAL VENT TERMINAL/COMBUSTION AIR ASSEMBLY FOR EACH BURNER. TYPICAL OF 2. INSTALL PER MANUFACTURERS RECOMMENDATIONS. PROVIDE FLASHING AT ROOF PENETRATION. PROVIDE AND INSTALL VENT PIPING AND COMBUSTION AIR PIPING PER MANUFACTURERS RECOMMENDATIONS.
2. FLEXIBLE CONNECTION.
3. PROVIDE AND INSTALL NEW ROOFTOP EXHAUST FAN. REMOVE AND REPLACE EXISTING ROOF CURB WITH NEW. PATCH AND REPAIR EXISTING ROOF.
4. PROVIDE AND INSTALL NEW GALVANIZED SHEETMETAL DUCT SECTION TO REPLACE EXISTING FAN. EXISTING DUCT IS APPROXIMATELY 36 INCH ROUND. FIELD VERIFY EXISTING CONDITIONS.
5. REMOVE EXISTING ROOFTOP HOOD. CAP WITH ¾" PLYWOOD AND SHEETMETAL CAP. SEAL WATER TIGHT. RETURN HOOD TO OWNER.
6. SUPPORT NEW UNIT FROM EXISTING JOISTS WITH SPRING ISOLATORS. EXISTING JOISTS SUPPORTING EXISTING MAKE-UP AIR UNIT SHALL NOT BE USED TO SUPPORT NEW UNIT. COORDINATE WITH STRUCTURAL DRAWINGS.
7. PROVIDE AND INSTALL NEW LOUVER IN EXISTING WALL. COORDINATE WITH STRUCTURAL DRAWINGS.
8. PROVIDE GALVANIZED SHEETMETAL DISCHARGE DEPTH SHALL MATCH DISCHARGE OPENING OF UNIT.
9. EXTEND AND CONNECT NEW LOUVER TO NEW UNIT INTAKE WITH GALVANIZED SHEETMETAL DUCT.
10. PROVIDE TEST AND BALANCE FOR MAU-1 AND EF-1. BALANCE AIR FLOW ACCORDING TO SCHEDULE.
11. TAG AND ID UNIT.
12. REMOTE MOUNTED MAKE-UP AIR UNIT CONTROLS. INTERLOCK PAINT BOOTH EXHAUST FAN TO OPERATE WHEN MAKE-UP AIR UNIT OPERATES.
13. EXTEND AND CONNECT A NEW GAS LINE FROM THE EXISTING MAIN TO NEW MAKE-UP AIR UNIT. PROVIDE SHUT-OFF VALVE AT CONNECTION.

State of Utah
Department of Administrative Services

Division of Facilities Construction & Management
4110 State Office Building
Salt Lake City, Utah 84114
Phone: (801) 538 - 3018
Fax: (801) 538 - 3267

Internet: http://www.dfcm.state.ut.us

CREATED BY: P+A architects

P+A architects
821 East Kensington Ave.
Salt Lake City, Utah 84105
P: 801.484.1161
F: 801.485.4640
e-mail parchitects@comcast.net

ARCHITECTURE | PLANNING | DESIGN

BUILDING NAME:

UINTAH BASIN APPLIED TECH. COLLEGE

PROJECT TITLE:

UINTAH BASIN APPLIED TECH. COLLEGE PAINT BOOTH EXPANSION

MARK	DATE	DESCRIPTION

ISSUE TYPE: CONSTRUCTION DOCUMENTS

ISSUE DATE: NOVEMBER 09, 2005

DFCM PROJECT NO: 05078250
CAD PROJECT NO: 2005-11
CAD DWG FILE:
DRAWN BY: E. JUAREZ
CHK'D BY: S. SHEPHERD

SHEET TITLE

MECHANICAL DEMOLITION FLOOR PLAN AND NEW FLOOR PLAN

SHEET NUMBER

M-101

SHEET 13 OF 15

Registered Professional Engineer
STEVEN H. SHEPHERD
No. 189989
11-9-05
State of Utah

MAKE-UP AIR UNIT SCHEDULE

SYMBOL	MANUFACTURER	MODEL	LOCATION	AIRFLOW (CFM)	EXT SP (IN)	NATURAL GAS HEATING INPUT (BTUH)	NATURAL GAS HEATING OUTPUT (BTUH)	ELECTRICAL MOTOR H.P.	MOTOR RPM	VOLT	PHASE	Hz.	MAX OPER. WEIGHT (LBS)	COMMENTS
MAU-1	REZNOR	SSCBL 800	INDOOR	8,100	0.7	(800,000)	(640,000)	7.5	1200	460	3	60	1300	(1)(2)(3)(4)

(1) SEPARATED-COMBUSTION, INDOOR HEATING AND VENTILATING UNIT CONSISTING OF BLOWER SECTION AND FURNACE SECTION.
(2) CAPACITIES BASED ON 5100 FEET ELEVATION. SEA LEVEL CAPACITIES IN ( ).
(3) PROVIDE A VERTICAL VENT TERMINAL AND CONCENTRIC ADAPTER WITH A VERTICAL VENT TERMINAL/COMBUSTION-AIR INLET ASSEMBLY FOR EACH FURNACE.
(4) STARTER AND DISCONNECT SHALL COME WITH UNIT.

EXHAUST FAN SCHEDULE

SYM	MANUFACTURER	MODEL NO.	CFM	STATIC PRESSURE IN WG.	H.P.	RPM	VOLTS/ PHASE/ CYCLE	AREA SERVED	CONTROL METHOD	COMMENTS
EF-1	LOREN-COOK	365 ACRU-HP	15,300	1.35	7.5	871	460/3/60	PAINT BOOTH	(A) (B) (C)	(1) (2) (3)

(1) ALL CAPACITIES AT 5100 FT. ELEVATION.
(2) ROOF MOUNTED UPBLAST EXHAUST FAN, COMPLETE WITH PRE-FAB ROOF CURB, MOTORIZED BACKDRAFT DAMPER, BIRD SCREEN, INTEGRAL THERMAL OVERLOAD PROTECTION AND SERVICE DISCONNECT.
(3) EXHAUST FAN TO BE SPARK RESISTANT CONSTRUCTION, MOTOR TO BE EXPLOSION PROOF. (DIV II CLASS I)
(A) CONTROL: ON-OFF WALL SWITCH BY DIV. 16
(B) CONTROL: INTERLOCK WITH EXISTING PAINT BOOTH BY DIV. 16
(C) CONTROL: INTERLOCK WITH MAKE-UP AIR UNIT



NOTE: MECHANICAL EQUIPMENT TO SET LEVEL. ORDER CURB TO COMPENSATE FOR ROOF SLOPE.

A4 ROOF HOOD SECTION DETAIL
SCALE: NOT TO SCALE

State of Utah
Department of Administrative Services
Division of Facilities Construction & Management
4110 State Office Building
Salt Lake City, Utah 84114
Phone: (801) 538 - 3018
Fax: (801) 538 - 3267
Internet: http://www.dfcm.state.ut.us

CREATED BY: P+A architects

P+A architects
821 East Kensington Ave.
Salt Lake City, Utah 84105
P: 801.484.1161
F: 801.485.4640
e-mail parchitects@comcast.net

ARCHITECTURE PLANNING DESIGN

BUILDING NAME:
UINTAH BASIN APPLIED TECH. COLLEGE

PROJECT TITLE:
UINTAH BASIN APPLIED TECH. COLLEGE PAINT BOOTH EXPANSION

MARK	DATE	DESCRIPTION

ISSUE TYPE: CONSTRUCTION DOCUMENTS

ISSUE DATE: NOVEMBER 09, 2005

DFCM PROJECT NO: 05078250
CAD PROJECT NO: 2005-11
CAD DWG FILE:
DRAWN BY: E. JUAREZ
CHK'D BY: S. SHEPHERD

SHEET TITLE
MECHANICAL SCHEDULES & DETAILS

SHEET NUMBER
M-501

SHEET 14 OF 15

Registered Professional Engineer
STEVEN T. SHEPHERD
No. 189989
11-9-05
State of Utah

EQUIPMENT SCHEDULE

MARK	QTY	ITEM DESCRIPTION	LOAD DATA							WIRE AND CONDUIT SIZE	OVERCURRENT PROTECTION			DISCONNECT			STARTER DATA												NOTES	MARK
			HP	kW	MCA	FLA	VOLT	PH	Hz		FURN BY	DEVICE	LOCATION	FURN BY	DEVICE	LOCATION	FURN BY	DEVICE	LOCATION	SIZE	SPEED	CTRL VOLT	SELECTOR SWITCH	PUSH BUTTON	PILOT LAMP	NORMALLY OPEN CONTACTS	NORMALLY CLOSED CONTACTS	PHASE FAILURE RELAY	SCHEMATIC REFERENCE	REMOTE CTRL		
MAU-1		MAKE UP AIR UNIT	7.5			11	480	3	60	3#10 THWN CU 1#10 GR, 3/4"C	E	30A/3P CB	PANEL 02	Q			Q														** 3	MAU-1
EF-1		EXHAUST FAN	7.5			11	480	3	60	3#10 THWN CU 1#10 GR, 3/4"C	E	30A/3P CB	PANEL 02	Q	30A3PNF NENA 3R	ADJ TO EQUIP	E	FVNR NENA 1	1	1	871		HOA			2	2				**,1,3	EF-1
EF-1		MOTORIZED DAMPER					120	1	60	2#12 THWN CU 1#12 GR, 3/4"C	E	20A/3P CB	PANEL 0	E	THERMAL SWITCH																4, 5	EF-1

NOTES
1. LOCATED IN ROOM ABOVE SPRAY ROOM
2. PROVIDE 120 VAC FOR CONTROL POWER AND MOTORIZED DAMPER
3. PROVIDE NEW 30A 3 POLE CIRCUIT BREAKER IN PANEL 02 TO MATCH EXISTING CIRCUIT BREAKERS IN PANEL.
4. FOR MOTORS LESS THAN 1 HP, IF MOTOR NAMEPLATE SHOWS THE MOTOR TO BE THERMALLY PROTECTED, A DISCONNECT MAY BE SUBSTITUTED FOR THE THERMAL SWITCH.
5. PROVIDE NEW 20A 1 POLE CIRCUIT BREAKER IN PANEL 0 TO MATCH EXISTING CIRCUIT BREAKERS IN PANEL.

SYMBOL LEGEND

SYMBOL	DESCRIPTION
REFERENCE AND LINE SYMBOLS	
100	ROOM OR SPACE NUMBER.
①	KEYNOTE INDICATOR.
1	REVISION INDICATOR.
CU-1	EQUIPMENT INDICATOR.
WIRING METHODS	
A-1,3,5	BRANCH CIRCUIT HOME RUN TO PANELBOARD: NUMBER OF ARROWS INDICATES NUMBER OF CIRCUITS. LETTER AND NUMBER NOTATIONS IDENTIFY PANEL AND CIRCUIT NUMBERS. USE #12 CONDUCTORS, EXCEPT #10 CONDUCTORS SHALL BE INSTALLED IF DISTANCES EXCEED 200 FEET.
J	JUNCTION BOX.
WIRING DEVICES	
WP	RECEPTACLE, DUPLEX WITH GROUND FAULT CIRCUIT INTERRUPTER, WEATHERPROOF: NEMA 5-20R.
ELECTRICAL POWER AND DISTRIBUTION	
	DISCONNECT SWITCH, FUSED.
	DISCONNECT SWITCH, UNFUSED.
	STARTER, COMBINATION WITH DISCONNECT SWITCH.
	PUSH BUTTON STATION START & STOP.

EQUIPMENT SCHEDULE KEY

E	DIVISION 16
Q	FURNISHED WITH THE EQUIPMENT
*	COORDINATE WITH THE DIVISION 15 TEMPERATURE CONTROL INSTALLER
**	AUTOMATIC CONTROL WIRING BY DIVISION 15
HP	HORSE POWER. IF MOTORS UNDER 1HP ARE SHOWN TO BE THERMALLY PROTECTED ON THEIR NAMEPLATES, A NON-FUSED DISCONNECT SWITCH MAY BE SUBSTITUTED FOR THE THERMAL SWITCH.
HOA	HAND OFF AUTO SWITCH
RTU	DISCONNECT SWITCH LOCATED AT ROOF TOP UNIT
STD	MANUFACTURER'S STANDARD
TBD	TO BE DETERMINED BY CONTRACTOR BASED ON EQUIPMENT FLA RATING ON NAMEPLATE
CC#	CONDUCTOR & CONDUIT SCHEDULE SYMBOL NUMBER
##A	FRAME SIZE OF DISCONNECT SWITCH
##AF	AMP RATING OF FUSES IN FUSED DISCONNECT SWITCH
NF	NON FUSED DISCONNECT SWITCH
#P	# OF POLES



A3 NEW ELECTRICAL PLAN
SCALE: 1/4" = 1'-0"

GENERAL SHEET NOTES

1. PANEL 0 & 02 IS LOCATED IN A ROOM 150' TO THE WEST AND 50' TO THE NORTH OF THE NEW EQUIPMENT. CONTRACTOR TO VISIT SITE AND LOCATE PANEL PRIOR TO BID.
2. PROVIDE CONDUIT AND CONDUCTOR TO PANELS AS PER EQUIPMENT SCHEDULE.

SHEET KEYNOTES

1. MOTOR STARTER IN ROOM BELOW FAN AND ABOVE PAINT ROOM.
2. DISCONNECT ADJACENT TO FAN.
3. TO PANEL "0" PROVIDE POWER FOR MOTORIZED DAMPER AND MOTOR STARTER CONTROL.
4. THERMAL SWITCH OR MOTORIZED DAMPER. PROVIDE 3/4" CONDUIT WITH 3EA #12 THHN. CONTROL DAMPER WITH AUX CONTACT ON FAN MOTOR STARTER SUCH THAT DAMPER OPENS WHEN FAN IS ON. DO NOT SWITCH POWER TO CONVENIENCE OUTLET.
5. PROVIDE 3/4" CONDUIT WITH 4EA #12 THHN FOR CONTROL. INTERLOCK EXHAUST FAN WITH MAU SUCH THAT PUSH BUTTON TURNS ON MAU AND MAU AUXILIARY CONTACT TURNS ON EXHAUST FAN. HAND POSITION ON EXHAUST FAN HOA SWITCH OVERRIDES INTERLOCK TO TURN ON FAN. PROVIDE GENERAL ELECTRIC CR2943-NA102W PUSH BUTTON STATION.

State of Utah
Department of Administrative Services
Division of Facilities Construction & Management
4110 State Office Building
Salt Lake City, Utah 84114
Phone: (801) 538 - 3018
Fax: (801) 538 - 3267
Internet: http://www.dfcm.state.ut.us

CREATED BY: P+A architects

P+A architects
821 East Kensington Ave.
Salt Lake City, Utah 84105
P: 801.484.1161
F: 801.485.4640
e-mail parchitects@comcast.net

ARCHITECTURE | PLANNING | DESIGN

BUILDING NAME:
UINTAH BASIN APPLIED TECH. COLLEGE

PROJECT TITLE:
UINTAH BASIN APPLIED TECH. COLLEGE PAINT BOOTH EXPANSION

MARK	DATE	DESCRIPTION

ISSUE TYPE: CONSTRUCTION DOCUMENTS

ISSUE DATE: NOVEMBER 09, 2005

DFCM PROJECT NO: 05078250
CAD PROJECT NO: 2005-11
CAD DWG FILE:
DRAWN BY: E. JUAREZ
CHK'D BY: S. SHEPHERD

SHEET TITLE
ELECTRICAL FLOOR PLAN

SHEET NUMBER
E-101

SHEET 15 OF 15

LICENSED PROFESSIONAL ENGINEER
No. 191471
TERRY L. TIPPETS
STATE OF UTAH